SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 **OPEN DATE:**

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) **NUMBER RECEIVED:** ( ) **OTHER** ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to amend and utilize Second and final renewal with Johnson Controls, Inc. (contract #9572-04), for piggyback GSA Contract #GS-07F-190CA, to include inspections and preventative maintenance along with scheduled service materials on Chiller and Chiller related equipment. The annual cost for Year 3 will be $61,452.37 ($8,778.91 per month). Period of service will be from February 1, 2020 through August 31, 2020. Total revised award amount not-to-exceed $3,911,868.38.

This award is to be funded by various accounts executed by contract amendment through Office of General Counsel, and processed by individual Purchase Order releases against the master blanket.

Attachments: Recommendation Memo, Vendor's Planned Service Proposal, Current Certificate of Insurance, Previous Award(s)

BUYER: Marilyn Laidler **RESPECTFULLY SUBMITTED**
MARILYN LAIDLER
GREGORY PEASE, CHIEF
PROCUREMENT DIVISION

CONCURRENCE BY: **Roy Birbal, Chief, Public Buildings Division**

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING _____ MEMBERS DISAPPROVING _____ DATE: _____

_____ _____ OTHER: _____

_____ _____

_____ _____

ACTION OF AWARDING AUTHORITY DATE _____

APPROVED _____ DISAPPROVED _____

OTHER _____

SIGNATURE OF AUTHENTICATION _____

City of Jacksonville, Florida

Lenny Curry, Mayor

Department of Public Works
Public Buildings Division
555 W. 44th Street
Jacksonville, FL 32208
(904) 255-4343
www.coj.net

ONE CITY. ONE JACKSONVILLE

January 10, 2020

MEMORANDUM

TO: Gregory W. Pease, Chief
Procurement Division

THRU: John P. Pappas, P. E., Director

FROM: Roy Birbal, Chief

SUBJECT: Johnson Controls, Inc.
PSC-0470-17 Piggybacking General Services Administration (GSA) Federal Supply Schedule Contract # GS-07F-190CA Schedule 84 for HVAC Equipment, Installation and Facility Services. Request for 2nd and Final Renewal (Year 3) of a Planned Service Proposal for HVAC Facility Services to Include Inspections and Preventative Maintenance along with Scheduled Service Materials on Chiller and Chiller Related Equipment.

The Public Buildings Division recommends approval to amend and increase award PSC-0470-17 to utilize the 2nd and final renewal (Year 3) of a Planned Service Proposal for HVAC Facility Services to include Inspections and Preventative Maintenance along with Scheduled Service Materials on Chiller and Chiller Related Equipment as described in the attached Johnson Controls, Inc. Planned Service Proposal (Exhibit 7) dated January 7, 2020 in connection with GSA Contract GS-07F-190CA Schedule 84.

The cost for Year 3 consisting of seven (7) months from February 1, 2020 through August 31, 2020 is Sixty One Thousand Four Hundred Fifty Two Dollars and Thirty-Seven Cents ($61,452.37) at $8,778.91 per month.

Buildings	Address
City Hall at St. James	117 W. Duval Street
Department of Health	515 W. 6th Street
Ed Ball Building	214 N. Hogan Street
Fire/Rescue Administration Building (EOC)	515 N. Julia Street
Police Memorial Building	501 E. Bay Street
Pre-Trial Detention Facility	500 E. Adams Street

The total revised maximum indebtedness will become $3,911,868.38.

Funding will be encumbered by individual releases against the master blanket, dependent on funding, the appropriate account and fiscal year. A formal contract amendment #9 to City Contract 9572-04 will be executed through the Office of General Counsel.

Your assistance in concurring with this recommendation for the respective award would be appreciated.

ab

If you have questions or need additional information, please contact Jim Lange in Public Buildings at 255-4340.

Attachments:

- Johnson Controls, Inc. Planned Service Proposal (Exhibit 7 to Contract 9572-04)
- Current Certificate of Insurance
- Latest Award

cc: Ann Brackin, Public Works Contracts and Finance Manager
Marilyn Laidler, Purchasing Analyst
Gene Trevail, Facility Manager
Jim Lange, Contract Administration Coordinator

Planned Service Proposal

EXHIBIT 7

Updated Planned Service Proposal

CUSTOMER
CITY OF JACKSONVILLE

LOCAL JOHNSON CONTROLS OFFICE
4820 EXECUTIVE PARK CT STE 109
JACKSONVILLE,FL 32216-6003

AGREEMENT START DATE
02/01/2020

PROPOSAL DATE
01/7/2020

ESTIMATE NO.
1-14L9JT2T

Partnering with you to deliver value-driven solutions

A Planned Service Agreement with Johnson Controls provides you with a customized service strategy designed around the needs of your facility. Our approach features a combination of scheduled, predictive and preventative maintenance services that focus on your goals.

As your building technology services partner, Johnson Controls delivers an unmatched service experience delivered by factory-trained, highly skilled technicians who optimize operations of the buildings we work with, creating productive and safe environments for the people within.

By integrating our service expertise with innovative processes and technologies, our value-driven planned service solutions deliver sustainable results, minimize equipment downtime and maximize occupant comfort.

YORK BY JOHNSON CONTROLS

METASYS BY JOHNSON CONTROLS

Johnson Controls

Executive Summary

PLANNED SERVICE PROPOSAL FOR CITY OF JACKSONVILLE

Dear Mr. Lange,

We value and appreciate your interest in Johnson Controls as a service provider for your building systems and are pleased to provide a value-driven maintenance solution for your facility. The enclosed proposal outlines the Planned Service Agreement we have developed on your facility.

Details are included in the Planned Service Agreement summary (Schedule A), but highlights are as follows:

- In this proposal we are offering a Basic service agreement covering the third year (7 months) of the initial agreement covering 2 year, 7 months starting on 02/01/2018 and ending 08/31/2020, in connection with GSA Contract GS-07F-190CA.
- **The agreement price for third year (02/01/2020 – 08/31/2020) is $61,452.37**; see Schedule A, Supplemental Price and Payment Terms.
- The equipment options and number of visits being provided for each piece of equipment are described in Schedule A, Equipment list.

As a manufacturer of both mechanical and controls systems, Johnson Controls has the expertise and resources to provide proper maintenance and repair services for your facility.

Again, thank you for your interest in Johnson Controls and we look forward to becoming your building technology services partner.

Please contact me if you have any questions.

Sincerely,

James Bryl Sr
Service Manager
(904) 733-1411

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Benefits of Planned Service

A Planned Service Agreement with Johnson Controls will allow you to optimize your building's facility performance, providing dependability, sustainability and energy efficiency. You'll get a value-driven solution that fits your specific goals, delivered with the attention of a local service company backed by the resources of a global organization.

With this Planned Service Agreement, Johnson Controls can help you achieve the following five objectives:

1. **Identify Energy Savings Opportunities**
   Since HVAC equipment accounts for a major portion of a building's energy usage, keeping your system performing at optimum levels may lead to a significant reduction in energy costs.

2. **Reduce Future Repair Costs**
   Routine maintenance may maximize the life of your equipment and may reduce equipment breakdowns.

3. **Extend Asset Life**
   Through proactive, factory-recommended maintenance, the life of your HVAC assets may be extended, maximizing the return on your investment.

4. **Ensure Productive Environments**
   Whether creating a comfortable place where employees can be productive or controlling a space to meet specialized needs, maintenance can help you achieve an optimal environment for the work that is being accomplished

5. **Promote Environmental Health and Safety**
   When proper indoor conditions and plant requirements are maintained, business outcomes may be improved by minimizing sick leave, reducing accidents, minimizing greenhouse gas emissions and managing refrigerant requirements.

All of the services we perform on your equipment are aligned with "The 5 Values of Planned Maintenance" and our technicians understand how the work they perform can help you accomplish your business objectives.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Personalized Account Management

A Planned Service Agreement also provides you with the support of an entire team that knows your site and can closely work with you on budget planning and asset management. Your local Johnson Controls account management team can help guide planned replacement, energy retrofits and other building improvement projects. You'll have peace of mind that an entire team of skilled professionals will be looking out for what is best for your facility and budget.

A Culture of Safety

Johnson Controls technicians take safety seriously and personally, and integrate it into everything they do. All of our technicians participate in regular and thorough safety training. Because of their personal commitment, we are a leader in the HVAC service industry for workplace safety performance. This means that you do not have to worry about us when we are on your site.



Commitment to Customer Satisfaction

Throughout the term of your Planned Service Agreement, we will periodically survey you and use your feedback to continue to make improvements to our service processes and products. Our goal is to deliver the most consistent and complete service experience possible. To meet this goal, we've developed and implemented standards and procedures to ensure you receive the ultimate service experience – every time.

Energy & Sustainability

A more sustainable world one building at a time – Johnson Controls is a company that started more than 125 years ago with a product that reduced energy use in buildings. We've been saving energy for customers ever since. Today, Johnson Controls is a global leader in creating smart environments where people live, work and play, helping to create a more comfortable, safe and sustainable world.

The Value of Integrity

Johnson Controls has a long, proud history of integrity. We do what we say we will do and stand behind our commitments. Our good reputation builds trust and loyalty. In recognition for our commitment to ethics across our global operations, we are honored to be named one of the World's Most Ethical Companies by Ethisphere Institute, a leading think tank dedicated to business ethics and corporate social responsibility. In addition, *Corporate Responsibility Magazine* recognizes Johnson Controls as one of the top companies in its annual "100 Best Corporate Citizens" list.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Service Plan Methodology

As part of the delivery of this Planned Service Agreement, Johnson Controls will dedicate a local customer service agent responsible for having a clear understanding of the agreement scope, and your facility procedures and protocols.

A high-level overview around our service delivery process is outlined below including scheduling, emergency service, on-site paperwork, communication and performing repairs outside of the agreement scope.

Scheduling

Preventative maintenance service will be scheduled using our automated service management system. In advance of the scheduled service visit, our technician is sent a notice of service to a smartphone. Once the technician acknowledges the request, your customer service agent will call or e-mail your on-site contact to let you know the start date and type of service scheduled.

The technician checks in, wears personal protective equipment, performs the task(s) as assigned, checks out with you and asks for a screen capture signature on the smartphone device. A work order is then e-mailed, faxed or printed for your records.

Emergency Services

Emergency service can be provided 7 days a week, 24 hours a day, 365 days a year. During normal business hours, emergency service will be coordinated by the customer service agent. After hours, weekends and holidays, the emergency service number transfers to the Johnson Controls after-hours call center and on-call technicians are dispatched as needed.

Johnson Controls is committed to dispatching a technician within hours of receiving your call through the service line. A work order is e-mailed, faxed or printed for your records. Depending on the terms of your agreement, you may incur charges for after hour services.

Communication

A detailed communication plan will be provided to you so you know how often we will provide information to you regarding your Planned Service Agreement. The communication plan will also provide you with your main contacts at Johnson Controls.

Approval Process for Non-Covered Items

Johnson Controls will adhere to your procurement process. No work will be performed outside of the agreement scope without prior approval. Johnson Controls will work with you closely to ensure your procurement process is followed before any non-covered item work is started.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Summary of Services and Options

Comprehensive and Operational Inspections

During comprehensive and operational inspections, Johnson Controls will perform routine checks of the equipment for common issues caused by normal wear and tear on the equipment. Additional tests can be run to confirm the equipment's performance.

Routine maintenance, such as lubrication, cleaning and tightening connections, can be performed depending on the type of equipment being serviced. Routine maintenance is one of the keys to the five values of maintenance – it can help identify energy saving opportunities, reduce future repair costs, extend asset life, ensure productive environments, and promote health and safety.

Chiller Tube Brushing

Dirt, minerals (scale), and/or biological elements (algae) on chiller tubes prevent the efficient transfer of heat from the chilled water to the cool refrigerant. This requires operation of the chiller unit at lower evaporator (chiller) temperatures to accomplish the same level or capacity of cooling to satisfy building load. Johnson Controls technicians will brush the tubes to improve heat transfer and system efficiency. When required, they will make recommendations for hard mineral (scale) removal. This service does not include chemical treatment required to control or eliminate biohazards such as Legionella unless chemical water treatment services have been added as a separate option.

Oil Analysis

By examining the oil, we can determine what part of the chiller is experiencing the most significant and harmful wear. Johnson Controls has been collecting data to statistically derive acceptable limits. We can also determine if there is a breakdown in the oil or if contaminants are affecting chiller operation.

Tower/Basin Cleaning

During operation, a cooling tower becomes a natural repository for wind-blown debris. This debris has a tendency to collect in the tower's sump/basin. Johnson Controls technicians will clean the tower and basin to prevent blockage and potential damage to critical system components. This service does not include chemical treatment required to control or eliminate biohazards such as Legionella unless chemical water treatment services have been added as a separate option.

Vibration Analysis - Chiller

Johnson Controls maintains the world's largest database of vibration signatures based on more than 50,000 chiller analyses. Data from your chiller is collected by Johnson Controls personnel and uploaded to our predictive diagnostics team for analysis. It is then compared with vibration standards which have been statistically derived from 20 years of compiled data using patented formulas. This allows you to identify and correct potential issues before they cause unscheduled downtime.

Vibration Analysis – Fan & Pump

Johnson Controls technicians will collect vibration data at various measurement points on the machine. This data is used to assess the condition of bearings, sheaves, belts and rotors. It also detects the presences of imbalance or misalignment. Repairs are followed up with another vibration analysis to ensure root problems have been identified and resolved.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

This page intentionally left blank

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Summary

Thank you for considering Johnson Controls as your building technology services partner. The following agreement document includes all the details surrounding your Planned Service Agreement.

With planned service from Johnson Controls, you'll get a value-driven solution that can help optimize your building controls and equipment performance, providing dependability, sustainability and energy efficiency. You'll get a solution that fits your specific goals, delivered with the attention of a local service company backed by the resources of a global organization.

We'll be your building technology services partner

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

Planned Service Agreement

Customer Name :	CITY OF JACKSONVILLE
Address:	117 W DUVAL ST STE 375 JACKSONVILLE,FL 32202-5725
Proposal Date:	01/07/2020
Estimate #:	1-14L9JT2T

Scope of Service

Johnson Controls, Inc. ("JCI") and the Customer (collectively the "Parties") agree Preventative Maintenance Services, as defined in Schedule A ("Services"), will be provided by JCI at the Customer's facility. This Planned Service Agreement, the Equipment List, Supplemental Price and Payment Terms, Terms and Conditions, and Schedules attached hereto and incorporated by this reference as if set forth fully herein (collectively the "Agreement"), cover the rights and obligations of both the Customer and JCI.

Extended Service Options for Premium Coverage

If Premium Coverage is selected, on-site repair services to the equipment will be provided as specified in this Agreement for the equipment listed in the attached Equipment List.

Equipment List

Only the equipment listed in the Equipment List will be covered as part of this Agreement. Any changes to the Equipment List must be agreed upon in writing by both Parties.

Term / Automatic Renewal

This Agreement covers contract year 3 (7 months) beginning 02/01/2020 and continuing until 08/31/2020. Original term for the agreement is from 02/01/2018 and continues until 08/31/2020.

Refrigerant Charges

Refrigerant is not included under this Agreement and will be billed separately to the Customer by JCI.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Price and Payment Terms

The total Contract Price for JCI's Services during the **3rd year (02/01/2020 – 08/31/2020)** of the Original Term is **$61,452.37**. This amount will be paid to JCI in Monthly installments. All payments will be due and payable within 30 days of the invoice date and such timely payment by Customer shall be a condition precedent to JCI's obligation to perform its Services. A penalty of one and a half percent (1.5%) of the amount due per month shall accrue for payments received after the payment due date.

Invoices will be sent to the following location:

PUBLIC BUILDINGS DIVISION
ATTN ACCOUNTS PAYABLE
117 W DUVAL ST
JACKSONVILLE,FL 32202

☐ In lieu of paper invoices sent to the location above, invoices should be emailed to the following email address: pbinvoicing@coj.net with a copy to jlange@coj.net

This proposal is valid for thirty days from the proposal date.

JOHNSON CONTROLS Inc.

By: James Bryt Sr	By:
Signature:	Signature:
Title: Service Manager Date:	Title: Date:
Signature:	Customer PO#:
Title: Date:	

JCI Branch: JOHNSON CNTRL JACKSONVILLE GAINESVILLE CB - 0N90
Address: 4820 EXECUTIVE PARK CT STE 109
JACKSONVILLE,FL 32216-6003
Branch Phone: (904) 733-1411
Branch Email:

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (phys ically, electron ically, or in any other med ia) without the express written permiss on of Johnson Controls, Inc

Schedule A - Equipment List

ED BALL BUILDING	214 N HOGAN ST JACKSONVILLE, FL 32202-4240

Chiller, Water Cooled, High Pressure Centrifugal, 450-799 Tons

Quantity: 2
Coverage Level: Basic

Services Provided	
1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Sample and Analysis
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #

Cooling Tower, Gravity Distribution, 600-1200 Tons

Quantity: 2
Coverage Level: Basic

Services Provided	
1	Operational
1	Comprehensive
1	Oil Change (Gear Box)
1	Tower Cleaning

Customer Tag	Manufacturer	Model #	Serial #

Chiller, Electro-Mechanical Starter (EM), Low Voltage, <260 FLA

Quantity: 2
Coverage Level: Basic

Services Provided	
1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #

Pump, Condenser, 51-100 HP

Quantity: 2
Coverage Level: Basic

Services Provided	
1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #

Pump, Chilled Water, 51-100 HP

Quantity: 2
Coverage Level: Basic

Services Provided	
1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

ED BALL BUILDING	214 N HOGAN ST JACKSONVILLE, FL 32202-4240

Contractor - Mechanical
Quantity: 1
Coverage Level: Basic

Services Provided
1 Contractor - Mechanical

Customer Tag	Manufacturer	Model #	Serial #

2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other medium) without the express written permission of Johnson Controls, Inc

HEALTH CENTER	515 W 6TH ST JACKSONVILLE, FL 32206-4324

Chiller, Water Cooled, Screw (Multiple Compressors), 121-240 Tons

Quantity: 1
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Sample and Analysis
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1	Trane	RTWD200F2D0 2A1A1AA2A1A1 Y1D0A40	U15E02191

Cooling Tower, Gravity Distribution, <300 Tons

Quantity: 1
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Oil Change (Gear Box)
1	Tower Cleaning

Customer Tag	Manufacturer	Model #	Serial #
Cooling Tower 1	Marley Cooling Towers		10047876-A1-NC34035M-11

Chiller, Electro-Mechanical Starter (EM), Low Voltage, <260 FLA

Quantity: 1
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1 Starter	Trane		1-S0ITW2P - FIELD UPDATE N

Pump, Chilled Water, 11-50 HP

Quantity: 2
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
	JCI_YORK		1-S0LC68C
	JCI_YORK		1-S0LC62P

Pump, Condenser, 11-50 HP

Quantity: 2
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

©2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

HEALTH CENTER	515 W 6TH ST JACKSONVILLE, FL 32206-4324

Customer Tag	Manufacturer	Model #	Serial #
	JCI_YORK		1-S0LGGSH
	JCI_YORK		1-S0LGGMH

Contractor - Mechanical

Quantity: 1

Coverage Level: Basic

Services Provided

1 Contractor - Mechanical

Customer Tag	Manufacturer	Model #	Serial #

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

PRE-TRIAL DETENTION CENTER	500 E ADAMS ST JACKSONVILLE, FL 32202-2813

Chiller, Water Cooled, Low Pressure Centrifugal, 250-449 Tons

Quantity: 3

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Sample and Analysis
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1	JCI_YORK	YTE3E3C2CME	MRP310872
Chiller 2	JCI_YORK	YTE3E3C2CME	MRP310871
Chiller 3	JCI_YORK	YTE3E3C2CME	MRP312280

Chiller, Solid State Starter (SSS), Low Voltage without Coolant, 261-510 FLA

Quantity: 3

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1 Starter	JCI_YORK		1-S0K7FIK
Chiller 2 Starter	JCI_YORK		1-S0K7FJF
Chiller 3 Starter	JCI_YORK		1-S0K7FKB

Pump, Chilled Water, 11-50 HP

Quantity: 3

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
CW Pump 1	JCI_YORK		1-S0K7FSS
CW Pump 2	JCI_YORK		1-S0K7FUY
CW Pump 3	JCI_YORK		1-S0K7FVU

Pump, Condenser, 11-50 HP

Quantity: 3

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Cond Pump 1	JCI_YORK		1-S0K7FWY
Cond Pump 2	JCI_YORK		1-S0K7G5D
Cond Pump 3	JCI_YORK		1-S0KPGEN

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

EOC	515 N JULIA ST JACKSONVILLE, FL 32202-4128

Chiller, Electro-Mechanical Starter (EM), Low Voltage, <260 FLA

Quantity: 2

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
	Carrier		1-S0LNPT0
	Trane		1-S0LNPS5

Chiller, Water Cooled, Screw (Single Compressor), <250 Tons

Quantity: 1

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Sample and Analysis
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #
Carrier Chiller	Carrier	30HXCI36RY-57 IKA	0812019882

Chiller, Water Cooled, Screw (Multiple Compressors), 121-240 Tons

Quantity: 1

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Sample and Analysis
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #
Trane Chiller	Trane	RTWD200F2D0 2A1A1AA2A1A1 Y1D0A40	U00C05608

Cooling Tower, Gravity Distribution, <300 Tons

Quantity: 2

Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Oil Change (Gear Box)
1	Tower Cleaning
1	Vibration Analysis (Fan)

Customer Tag	Manufacturer	Model #	Serial #
	Marley Cooling Towers		1-S0LNPKQ
Cooling Tower 1	Marley Cooling Towers		1-S0LNPJU

Pump, Chilled Water, 11-50 HP

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other medium) without the express written permission of Johnson Controls, Inc

EOC

515 N JULIA ST
JACKSONVILLE, FL 32202-4128

Quantity: 3
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
	JCI_YORK		1-S0M55N3
	JCI_YORK		1-S0M55MH
	JCI_YORK		1-S0M55IK

Pump, Condenser, 11-50 HP

Quantity: 3
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
	JCI_YORK		1-S0LNPPV
	JCI_YORK		1-S0LNPP9
	JCI_YORK		1-S0LNPOE

Contractor - Mechanical

Quantity: 1
Coverage Level: Basic

Services Provided

1	Contractor - Mechanical

Customer Tag	Manufacturer	Model #	Serial #

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

ST JAMES BUILDING	117 W DUVAL ST JACKSONVILLE, FL 32202-3700

Pump, Chilled Water, 11-50 HP

Quantity: 4
Coverage Level: Basic

Services Provided
1 Operational
1 Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
CW Pump 1	Write-In		1-S07HL98
CW Pump 2	Write-In		1-S099I6Y
CW Pump 3	Write-In		1-S099I8M
CW Pump 4	Write-In		1-S099I8W

Pump, Condenser, 11-50 HP

Quantity: 4
Coverage Level: Basic

Services Provided
1 Operational
1 Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Cond Pump 1	Write-In		1-S099I96
Cond Pump 2	Write-In		1-S099I9G
Cond Pump 3	Write-In		1-S099I9Q
Cond Pump 4	Write-In		1-S099IA0

Chiller, Electro-Mechanical Starter (EM), Low Voltage, <260 FLA

Quantity: 3
Coverage Level: Basic

Services Provided
1 Operational
1 Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1 Starter	Trane		1-S099I6C
Chiller 2 Starter	Trane		1-S07HLJQ
Chiller 3 Starter	Trane		1-S07HLNC

Chiller, Water Cooled, Screw (Single Compressor), 250-449 Tons

Quantity: 2
Coverage Level: Basic

Services Provided
1 Operational

Customer Tag	Manufacturer	Model #	Serial #
Chiller 1	Trane	RTHB300FLE00 LWP000UNN3LF 3LFVOU	U96J07033
Chiller 2	Trane	RTHB300FLE00 LWP000UNN3LF 3LFVOU	U96J07034

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

ST JAMES BUILDING	117 W DUVAL ST JACKSONVILLE, FL 32202-3700

Chiller, Water Cooled, Screw (Multiple Compressors), 80-120 Tons

Quantity: 1

Coverage Level: Basic

Services Provided

1 Operational

Customer Tag	Manufacturer	Model #	Serial #
Chiller 3	Trane	RTWA0904YB01 D1D0W	U96K07984

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

POLICE MEMORIAL BUILDING	501 E BAY ST JACKSONVILLE, FL 32202-2927

Cooling Tower, Gravity Distribution, <300 Tons

Quantity: 2
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Oil Change (Gear Box)
1	Tower Cleaning

Customer Tag	Manufacturer	Model #	Serial #
Cooling Tower 1	Marley Cooling Towers		1-S0EG429
Cooling Tower 2	Marley Cooling Towers		1-S0EG4CC

Chiller, Water Cooled, VSD Screw (Single Compressor), 120-300 Tons

Quantity: 1
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive
1	Condenser Tube Brushing (removal and replacement of one head only)
1	Oil Analysis (1 Circuit)
1	Vibration Analysis

Customer Tag	Manufacturer	Model #	Serial #
York Chiller	JCI_YORK	YVWAMDM4EE AE0250SAX46B XX5S5XNA	2LAM022402

Pump, Chilled Water, 11-50 HP

Quantity: 2
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
CW Pump 1	JCI_YORK		1-S0EG4EW
CW Pump 2	JCI_YORK		1-S0EG4G1

Pump, Condenser, 11-50 HP

Quantity: 2
Coverage Level: Basic

Services Provided

1	Operational
1	Comprehensive

Customer Tag	Manufacturer	Model #	Serial #
Cond Pump 1	JCI_YORK		1-S0ERNL3
Cond Pump 2	JCI_YORK		1-S0ERNLY

Contractor - Mechanical

Quantity: 1
Coverage Level: Basic

Services Provided

1	Contractor - Mechanical

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

POLICE MEMORIAL BUILDING	501 E BAY ST JACKSONVILLE, FL 32202-2927

Customer Tag	Manufacturer	Model #	Serial #

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Equipment Tasking

Chiller, Electro-Mechanical Starter (EM), Low Voltage, <260 FLA

Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for proper EM operation Measure and record operating amperages and voltages if appropriate instrumentation is present Perform low voltage lock-out and tag-out procedure Inspect starter contacts for signs of wear Inspect filters, clean and/or replace as required Meg compressor motor Check and tighten electrical connections Check for heat damage Clean inside the EM cabinet Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Measure and record operating amperages and voltages if appropriate instrumentation is present Check for proper fan operation (if applicable) Inspect filters, clean and/or replace as required Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative

Chiller, Solid State Starter (SSS), Low Voltage without Coolant, 261-510 FLA

Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work

2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper SSS operation and recorded fault histories Inspect filters, clean and/or replace as required Meg compressor motor Check and tighten electrical connections Check for heat damage Clean inside the SSS cabinet Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper SSS operation and recorded fault histories Check for proper fan operation Inspect filters, clean and/or replace as required Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, High Pressure Centrifugal, 450-799 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Conduct refrigerant leak check Check compressor oil level(s) Change oil filters (isolation valves must be present and functional) Change oil educter filter dryer (isolation valves must be present and functional) Lubricate and check capacity control and linkage Verify oil heater operation Check and tighten electrical connections Perform preventative procedures to flow proving devices Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

	Document tasks performed during visit and report any observations to appropriate customer representative
Condenser Tube Brushing (removal and replacement of one head only)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI Ground Fault Circuit Interrupter safety process while working with electrical tool and equipment All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Isolate tubes Drain water from tubes Remove head Mechanically brush tubes Replace gasket Replace head Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Sample and Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove sample in approved container Drop off for analysis Label and complete paperwork indicating present operating conditions Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant levels Check compressor oil level(s) Check capacity control and linkage Check for proper oil temperature and pressure Lubricate motor bearings (per manufacturer's recommendations)

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Visually inspect for refrigerant and oil leaks Check for unusual noise and vibration Check overall condition of unit Record oil level in seal oil bottle Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, Low Pressure Centrifugal, 250-449 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check compressor oil level(s) Change oil filters (isolation valves must be present and functional) Change oil educter filter dryer (isolation valves must be present and functional) Check for proper purge operation Verify leak integrity of machine via purge count Change purge filter dryers/strainers Lubricate and check capacity control and linkage Verify oil heater operation Check and tighten electrical connections Perform preventative procedures to flow proving devices Lubricate motor bearings (per manufacturer's recommendations) Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Condenser Tube Brushing (removal and replacement of one head only)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI Ground Fault Circuit Interrupter safety process while working with electrical tool and equipment All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Isolate tubes Drain water from tubes Remove head Mechanically brush tubes Replace gasket Replace head Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Sample and Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove sample in approved container Drop off for analysis Label and complete paperwork indicating present operating conditions Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant levels Check compressor oil level(s) Check capacity control and linkage Check for proper oil temperature and pressure Check for proper purge operation Verify leak integrity of machine via purge count Visually inspect for refrigerant and oil leaks Check for unusual noise and vibration Check overall condition of unit

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Record oil level in seal oil bottle Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, Screw (Multiple Compressors), 121-240 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Conduct refrigerant leak check Check oil separator level Verify oil heater operation Perform lock-out and tag-out procedure Inspect contactors for wear Meg compressor motors and record results Check and tighten electrical connections Perform preventative procedures to flow proving devices Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Condenser Tube Brushing (removal and replacement of one	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

head only)	Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI Ground Fault Circuit Interrupter safety process while working with electrical tool and equipment All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Isolate tubes Drain water from tubes Remove head Mechanically brush tubes Replace gasket Replace head Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Sample and Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove sample in approved container Drop off for analysis Label and complete paperwork indicating present operating conditions Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant charge (sight glass) Check oil separator level Check for proper capacity control operation Check for proper oil temperature and pressure Check for visual signs of refrigerant/oil leak(s) Check for unusual noise and vibration Check overall condition of unit Check for proper operation of oil return system

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

	Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, Screw (Multiple Compressors), 80-120 Tons
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant charge (sight glass) Check oil separator level Check for proper capacity control operation Check for proper oil temperature and pressure Check for visual signs of refrigerant/oil leak(s) Check for unusual noise and vibration Check overall condition of unit Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, Screw (Single Compressor), 250-449 Tons
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

	Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant charge (sight glass) Check oil separator level Check for proper capacity control operation Check for proper oil temperature and pressure Check for visual signs of refrigerant/oil leak(s) Check for unusual noise and vibration Check overall condition of unit Record oil level in seal oil bottle Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, Screw (Single Compressor), <250 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Conduct refrigerant leak check Check oil separator level Record oil level in seal oil bottle Change oil filters (isolation valves must be present and functional) Change oil educter filter dryer (isolation valves must be present and functional) Verify oil heater operation Check and tighten electrical connections Perform preventative procedures to flow proving devices Lubricate motor bearings (per manufacturer's recommendations) Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Condenser Tube Brushing (removal and	Use appropriate eye protection in work environment Use appropriate Head protection on worksite

2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

replacement of one head only)	Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI Ground Fault Circuit Interrupter safety process while working with electrical tool and equipment All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Isolate tubes Drain water from tubes Remove head Mechanically brush tubes Replace gasket Replace head Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Sample and Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove sample in approved container Drop off for analysis Label and complete paperwork indicating present operating conditions Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant charge (sight glass) Check oil separator level Check for proper capacity control operation Check for proper oil temperature and pressure Check for visual signs of refrigerant/oil leak(s) Check for unusual noise and vibration Check overall condition of unit

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Record oil level in seal oil bottle Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Chiller, Water Cooled, VSD Screw (Single Compressor), 120-300 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Conduct refrigerant leak check Check oil separator level Verify oil heater operation Perform lock-out and tag-out procedure Inspect contactors for wear Meg compressor motors and record results Check and tighten electrical connections Perform preventative procedures to flow proving devices Perform VSD coolant change procedures Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Condenser Tube Brushing (removal and	Use appropriate eye protection in work environment Use appropriate Head protection on worksite

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other medium) without the express written permission of Johnson Controls, Inc.

replacement of one head only)	Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI Ground Fault Circuit Interrupter safety process while working with electrical tool and equipment All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Isolate tubes Drain water from tubes Remove head Mechanically brush tubes Replace gasket Replace head Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Analysis (1 Circuit)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove sample in approved container Drop off for analysis Label and complete paperwork indicating present operating conditions Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts Use and follow the JCI safety policy for working with CFC, HCFC and HRC refrigerants All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Review control panel for proper operation and recorded fault histories Check for proper condenser and chilled water flow Check system pressures and temperatures Check refrigerant charge (sight glass) Check oil separator level Check for proper capacity control operation Check for proper oil temperature and pressure Check for visual signs of refrigerant/oil leak(s) Check for unusual noise and vibration Check overall condition of unit

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Check for proper operation of oil return system Record and log all operating parameters Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Cooling Tower, Gravity Distribution, 600-1200 Tons
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check condition of sump and basin Check for proper operation of make up water controller and adjust as needed Disassemble and clean sump level sensor (if applicable) Check for proper condenser water temperature control (if applicable) Check operation of bypass valve (if applicable) Check condition of tower fill Check for blockage in water distributers Check fan mechanical drive system and lubricate per manufacturer's recommendation Check belt(s) (if applicable) Check and tighten electrical connections Check operation of basin heater (if applicable) Check tower sump screens Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Change (Gear Box)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Use and follow the JCI safety policy for Fall Protection while performing work
Use and follow the JCI Ladder Safety processes while performing work
Use and follow the JCI Lock-out Tag-out on all electrical machinery
Use and follow the JCI process for handling and working with Used Oil
All work must be performed in accordance with Johnson Controls safety policies
Check with appropriate customer representative for operational deficiencies
Remove used oil
Refill unit with new manufacturer recommended oil
Energize unit
Remove and dispose any debris from any maintenance activity
Document tasks performed during visit and report any observations to appropriate customer representative

Operational

Use appropriate eye protection in work environment
Use appropriate Head protection on worksite
Use appropriate hand gloves on worksite
Use and follow the JCI safety policy for Fall Protection while performing work
Use and follow the JCI Ladder Safety processes while performing work
Use and follow the JCI Lock-out Tag-out on all electrical machinery
Use appropriate Arc/flash personal protective equipment on voltages over 240 volts
All work must be performed in accordance with Johnson Controls safety policies
Check with appropriate customer representative for operational deficiencies
Check condition of sump and basin
Check for proper operation of make up water controller
Check for proper condenser water temperature control (if applicable)
Check operation of bypass valve (if applicable)
Check condition of tower fill
Check for blockage in water distributers
Check fan mechanical drive system
Check belt(s) (if applicable)
Check operation of basin heater (if applicable)
Check for unusual noise and vibration
Check overall condition of unit
Document tasks performed during visit and report any observations to appropriate customer representative

Tower Cleaning

Use appropriate eye protection in work environment
Use appropriate Head protection on worksite
Use appropriate hand gloves on worksite
Use and follow the JCI safety policy for Fall Protection while performing work
Use and follow the JCI Ladder Safety processes while performing work
Use and follow the JCI Lock-out Tag-out on all electrical machinery
Use appropriate Arc/flash personal protective equipment on voltages over 240 volts
All work must be performed in accordance with Johnson Controls safety policies
Check with appropriate customer representative for operational deficiencies
Drain tower and basin
Remove soot and debris
Clean basin
Fill tower and basin
Remove and dispose any debris from any maintenance activity
Document tasks performed during visit and report any observations to appropriate customer representative

Cooling Tower, Gravity Distribution, <300 Tons

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check condition of sump and basin Check for proper operation of make up water controller and adjust as needed Disassemble and clean sump level sensor (if applicable) Check for proper condenser water temperature control (if applicable) Check operation of bypass valve (if applicable) Check condition of tower fill Check for blockage in water distributers Check fan mechanical drive system and lubricate per manufacturer's recommendation Check belt(s) (if applicable) Check and tighten electrical connections Check operation of basin heater (if applicable) Check tower sump screens Check for unusual noise and vibration Check overall condition of unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Oil Change (Gear Box)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use and follow the JCI process for handling and working with Used Oil All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Remove used oil Refill unit with new manufacturer recommended oil Energize unit Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check condition of sump and basin Check for proper operation of make up water controller Check for proper condenser water temperature control (if applicable) Check operation of bypass valve (if applicable)

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Check condition of tower fill Check for blockage in water distributers Check fan mechanical drive system Check belt(s) (if applicable) Check operation of basin heater (if applicable) Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
Tower Cleaning	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Drain tower and basin Remove soot and debris Clean basin Fill tower and basin Remove and dispose any debris from any maintenance activity Document tasks performed during visit and report any observations to appropriate customer representative
Vibration Analysis (Fan)	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Record equipment specific information for reference Install pads and labels (if applicable) Install sensors in proper location. Start equipment and run at normal operating conditions. Record readings and remove sensors. Submit readings for report generation and deliver to customer with recommendations. Document tasks performed during visit and report any observations to appropriate customer representative
	Pump, Chilled Water, 11-50 HP
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies

2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Check with appropriate customer representative for operational deficiencies Check for leaks Check coupling Lubricate pump and motor bearing(s) per manufacturer's recommendation Record and log all operating parameters Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check pressures Visually inspect coupling Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
	Pump, Chilled Water, 51-100 HP
Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check coupling Lubricate pump and motor bearing(s) per manufacturer's recommendation Record and log all operating parameters Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

All work must be performed in accordance with Johnson Controls safety policies
Check with appropriate customer representative for operational deficiencies
Check for leaks
Check pressures
Visually inspect coupling
Check for unusual noise and vibration
Check overall condition of unit
Document tasks performed during visit and report any observations to appropriate customer representative

Pump, Condenser, 11-50 HP

Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check coupling Lubricate pump and motor bearing(s) per manufacturer's recommendation Record and log all operating parameters Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check pressures Visually inspect coupling Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative

Pump, Condenser, 51-100 HP

Comprehensive	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

	Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check coupling Lubricate pump and motor bearing(s) per manufacturer's recommendation Record and log all operating parameters Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative
Operational	Use appropriate eye protection in work environment Use appropriate Head protection on worksite Use appropriate hand gloves on worksite Use and follow the JCI safety policy for Fall Protection while performing work Use and follow the JCI Ladder Safety processes while performing work Use and follow the JCI Lock-out Tag-out on all electrical machinery Use appropriate Arc/flash personal protective equipment on voltages over 240 volts All work must be performed in accordance with Johnson Controls safety policies Check with appropriate customer representative for operational deficiencies Check for leaks Check pressures Visually inspect coupling Check for unusual noise and vibration Check overall condition of unit Document tasks performed during visit and report any observations to appropriate customer representative

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

Supplemental Price & Payment Terms (Applies to Multi-Year Contracts Only)

Year	Total Annual Dollar Amount	Payment Frequency	Monthly Amount
1	$67,500.00	Monthly	$5,625.00
2	$60,903.00	Monthly	$5,075.50
3	$61,452.37	Monthly	$8,778.91

Sixty (60) days prior to beginning of each contract period (year), pricing will be confirmed based on current GSA approved rates in GSA Contract GS-07F-190CA.

Year 1 – February 01, 2018 – January 31, 2019
Year 2 - February 01, 2019 – January 31, 2020
Year 3 - February 01, 2020 – August 31, 2020
(partial year – 7 months based on GSA Contract Expiration)

Contract dates are based on the period defined by the current GSA schedule. Extensions in the GSA schedule can be applied to this contract, upon agreement by each party.

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

Special Additions and Exceptions

Refrigerant is not included in the pricing

In Contract year 3 (7 months), pricing is based upon work delivery plan for the covered buildings Annuals are typically scheduled one each year, within a 3 month window.

Repair Labor and Repair Material outside the scope of these defined services will be provided using GSA approve rates in GSA Contract GS-07-190CA.

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

TERMS AND CONDITIONS
DEFINITIONS

CONNECTED SERVICES are the services and related equipment that allow JCI to access, monitor, and trend data remotely, and which may be available for certain types of Covered Equipment.

CONTRACT PRICE means the price that Customer shall pay to JCI for the Services.

COVERED EQUIPMENT means the equipment for which Services are to be provided under this Agreement. Covered Equipment is set forth in Schedule A - Equipment List.

EQUIPMENT FAILURE means the failure, under normal and expected working conditions, of moving parts or electric or electronic components of the Covered Equipment that are necessary for its operation.

PREMISES means those Customer premises where the Covered Equipment is located or Services performed pursuant to this Agreement.

REMOTE MONITORING SERVICES means remote monitoring of Covered Equipment and/or systems including building automation, HVAC equipment, and fire alarm, intrusion, and/or other life safety systems for alarm and event notifications using a UL Certified Central Station.

REMOTE OPERATIONS CENTER (ROC) is the department at JCI that remotely monitors alarm and industrial (HVAC) process signals.

REMOTE OPERATING SERVICES means remote interrogation, modification and/or operation of building automation, HVAC equipment, and/or other Covered Equipment.

REPAIR LABOR is the labor necessary to restore Covered Equipment to working condition following an Equipment Failure, but does not include services relating to total equipment replacement due to obsolescence or unavailability of parts.

REPAIR MATERIALS are the parts and materials necessary to restore Covered Equipment to working condition following an Equipment Failure, but excludes total equipment replacement due to obsolescence or unavailability of parts, unless excluded from the Agreement. At JCI's option, Repair Materials may be new, used, or reconditioned.

SCHEDULED SERVICE MATERIALS are the materials required to perform Scheduled Service Visits on Covered Equipment, unless excluded from the Agreement.

SCHEDULED SERVICE VISITS are the on-site labor visits required to perform JCI recommended inspections and preventive maintenance on Covered Equipment.

SERVICES are the work, materials, labor, service visits, and repairs to be provided by JCI pursuant to this Agreement except that the Services do not include the provision of any software products or digital or cloud services, which are provided under separate terms and conditions referenced in Section P herein.

A. JCI'S SERVICES FOR COVERED EQUIPMENT

1. **BASIC COVERAGE** means Scheduled Service Visits, plus Scheduled Service Materials (unless excluded from this Agreement). No parts, equipment, Repair Labor or Repair Materials are provided for under BASIC COVERAGE.

2. **PREMIUM COVERAGE** means BASIC COVERAGE plus Repair Labor, plus Repair Materials (unless excluded from the Agreement). If Customer has ordered PREMIUM COVERAGE, JCI will inspect the Covered Equipment within forty-five (45) days of the date of this Agreement, or as seasonal or operational conditions permit. JCI will then advise Customer if JCI finds any Covered Equipment not in working order or in need of repair. With Customer's approval, JCI will perform the work necessary to put the Covered Equipment in proper working condition, subject to the terms of this Agreement. Customer will pay for such work at JCI's standard rates for parts and labor in effect at the time that the work is performed. If Customer does not want JCI to perform the work identified as necessary by JCI, any equipment thereby affected will be removed from the list of Covered Equipment, and the Contract Price will be adjusted accordingly. Should Customer not make JCI's recommended repairs or proceed with the modified PREMIUM COVERAGE, JCI reserves the right to invoice Customer for the cost of the initial equipment inspection.

3. **EXTENDED SERVICE** means Services performed outside JCI's normal business hours and is available only if Customer has PREMIUM COVERAGE. Extended Service is available either 24/5 or 24/7, at Customer's election. The price for Extended Service, if chosen by Customer, is part of the total Contract Price.

4. **CONNECTED SERVICES.** If Customer has purchased Connected Chiller Services on any Covered Equipment as more fully described in Schedule A, JCI will provide a cellular modem ("Gateway Device" owned by JCI) or Customer will supply a network connection suitable to establish a remote connection with Customer's Equipment to permit JCI to perform troubleshooting, quarterly health reports, and meet service levels, including remote diagnostic, monitoring and repair services. Customer will benefit from being able to access chiller information from JCI Connected Chillers from a mobile smart device. JCI will not use Connected Services to remotely operate or make changes to Customer's Equipment. The Gateway Device shall remain JCI's property, and JCI may upon reasonable notice remove it at any time. JCI makes no any warranty or guarantee relating to the Connected Services. For Equipment not covered by a current Service Agreement, JCI disclaims any obligation to monitor such products via a remote connection or advise Customer of any possible Equipment error or malfunction.

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

5. **REMOTE MONITORING SERVICES OR REMOTE OPERATING SERVICES.** If Remote Monitoring Services or Remote Operating Services are provided, Customer agrees to furnish JCI with a list of the names, titles, addresses, email addresses, and phone numbers of all persons authorized to be contacted by, or be able to contact the ROC to perform specific agreed upon actions with the appropriate authority. If JCI's Services include "Remote Monitoring Services with Open and Close," Customer also agrees to furnish JCI with Customer's daily and holiday opening and closing schedules. Customer agrees to maintain and update the call lists with accurate information. Customer further agrees to notify JCI of such changes as soon as possible. JCI/ROC is not responsible to find new contacts/numbers if the contacts on the call lists cannot be reached. A maximum of three contacts are allowed for any time of the day. If none of those contacts can be reached, then neither JCI nor the ROC are responsible for damages. Customer is responsible for any and all costs and expenses arising from Customer's failure to provide timely updates for any of the contact information submitted to the ROC.

6. **CUSTOMER SERVICE INFORMATION PORTAL.** Customer may be able to utilize JCI's Customer Service Information Portal during the term of the Agreement, pursuant to the then applicable Terms of Use Agreement.

B. OUT OF SCOPE SERVICES

If, during any Service Visit, JCI detects a defect in any of Customer's equipment that is not Covered Equipment under this Agreement (an "Out of Scope Defect"), JCI may (but shall have no obligation to) notify Customer of such Out of Scope Defect. If Customer elects for JCI to repair such Out of Scope Defect, or if JCI otherwise performs any Services or provides any materials, parts, or equipment outside the scope of the Services (collectively, "Out of Scope Services"), Customer shall direct JCI to perform such Out of Scope Services in writing, and Customer shall pay for such Out of Scope Services at JCI's standard fees or hourly rates. If, after receiving notice of an Out of Scope Defect, Customer elects not to engage JCI to repair such Out of Scope Defect, Customer shall defend and indemnify JCI from and against any and all losses, damages, claims, costs and expenses arising directly or indirectly out of such Out of Scope Defect. Any Out of Scope Services performed by JCI at the direction of Customer pursuant to this Section shall be subject to the terms of this Agreement.

C. EXCLUSIONS

JCI's Services and warranty obligations expressly exclude:

(a) the repair or replacement of ductwork, casings, cabinets, structural supports, tower fill/slats/basin, hydronic and pneumatic piping, and vessels, gaskets, and piping not normally replaced or maintained on a scheduled basis, and removal of oil from pneumatic piping;

(b) disposal of hazardous wastes (except as otherwise expressly provided herein);

(c) disinfecting of chiller condenser water systems and other components for biohazards, such as but not limited to, Legionella unless explicitly set forth in the scope of services between the parties. Unless explicitly provide for within the scope of services, this is Out of Scope Services and the Customer's exclusive responsibility to make arrangements for such services with a provider other than JCI. Mentions of chiller tube cleaning, condenser cleaning, cooling tower cleaning or boiler tube cleaning in any scope of services, only involve work to remove normal buildup of debris and scale using tube brush cleaning, pressure washing or acid flushing. Reference to such cleaning does not include chemical cleaning, disinfection or chemical water treatment required to eliminate, control or disinfect against biohazards such as but not limited to Legionella,

(d) supplies, accessories, or any items normally consumed during the use of Covered Equipment, such as ribbons, bulbs and paper;

(e) the furnishing of materials and supplies for painting or refinishing equipment;

(f) the repair or replacement of wire in conduit, buried cable/transmission lines, or the like, if not normally replaced or maintained on a scheduled basis;

(g) replacement of obsolete parts; and

(h) damages of any kind, including but not limited to personal injury, death, property damage, and the costs of repairs or service resulting from:

- abuse, misuse, alterations, adjustments, attachments, combinations, modifications, or repairs to Covered Equipment not performed, provided, or approved in writing by JCI,
- equipment not covered by this Agreement or attachments made to Covered Equipment,
- acts or omissions of the Customer, including but not limited to the failure of the Customer to fulfill the Customer Obligations and Commitments to JCI as described in Section F of this Agreement, operator error, Customer's failure to conduct preventive maintenance, issues resulting from Customer's previous denial of JCI access to the Covered Equipment, and Customer's failure to keep the site clean and free of dust, sand, or other particles or debris, unless such conditions are previously expressly acknowledged by JCI in writing;
- use of the Covered Equipment in a manner or environment, or for any purpose, for which it was not designed by the manufacturer,
- site-related and environmental conditions, including but not limited to power failures and fluctuations in electrical current (or "power surges") and biohazards such as but not limited to Legionella associated with condenser water, cooling tower systems and subcomponent systems;
- the effects of erosion, corrosion, acid cleaning, or damage from unexpected or especially severe freezing weather,
- issues or failures not specifically covered by this Agreement, or
- occurrences beyond JCI's reasonable control and without JCI's fault or negligence

D. PAYMENT TERMS; PRICE ADJUSTMENTS

Fees and other amounts due hereunder are due upon receipt of the invoice and shall be paid by Customer within thirty (30) days. Such payment is a condition precedent to JCI's obligation to perform Services under the Agreement. Any invoice disputes must be identified in writing by Customer within 21 days of the date of invoice. Payments of any disputed amounts are due and payable upon resolution. All other amounts remain due within 30 days.

2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

Failure by Customer to make payments when due will give JCI, without prejudice to any other right or remedy, the right to: (i) to stop performing any Services, withhold deliveries of Equipment and other materials, terminate or suspend any software licenses provided hereunder and/or terminate this Agreement, and (ii) charge Customer interest on the amounts unpaid at a rate equal to the lesser of one and one-half (1.5) percent per month or the maximum rate permitted under applicable law, until payment is made in full. Customer will pay all of JCI's reasonable collection costs (including legal fees and expenses). In the event of Customer's default, the balance of any outstanding amounts will be immediately due and payable.

JCI may increase prices upon notice to the Customer to reflect increases in material and labor costs. In issuing any purchase order related to this Agreement, and notwithstanding any language to the contrary therein, Customer acknowledges and agrees that any and all JCI invoices for an amount greater than $25,000 shall be paid only via wire transfer, check, or money order. If this Agreement is renewed, JCI will provide Customer with notice of any adjustments in the Contract Price applicable to any renewal period no later than forty-five (45) days prior to the commencement of that renewal period. Unless Customer terminates the Agreement at least thirty (30) days prior to the start of such renewal period, the adjusted price shall be the price for the renewal period.

E. WARRANTIES

JCI warrants its Services will be provided in a good and workmanlike manner for 90 days from the date of Services. If JCI receives written notice of a breach of this warranty prior to the end of this warranty period, JCI will re-perform any non-conforming Services at no additional charge within a commercially reasonable time of the notification.

JCI warrants that equipment manufactured or labeled by Johnson Controls, Inc. shall be free from defects in material and workmanship arising from normal usage for a period of 90 days. If JCI installs or furnishes a piece of equipment under this Agreement, and that equipment is covered by a warranty from a manufacturer other than JCI, JCI will transfer the benefits of that manufacturer's warranty, if any, to Customer and such warranty remedies are exclusive for that equipment. All transportation charges incurred in connection with the warranty for equipment and/or materials not covered under this Agreement shall be borne by Customer. Except as provided herein, if JCI receives written notice of a breach of this warranty prior to the end of this warranty period, JCI will repair or replace (at JCI's option) the defective equipment.

These warranties do not extend to any Services or equipment that have been misused, altered, or repaired by Customer or third parties without the supervision of and prior written approval of JCI, or if JCI serial numbers or warranty decals have been removed or altered. All replaced parts or equipment shall become JCI's property. This warranty is not assignable. Warranty service will be provided during normal business hours, excluding holidays. The remedies set forth herein shall be Customer's sole and exclusive remedy with regards to any warranty claim under this Agreement. Any lawsuit based upon the warranty must be brought no later than one (1) year after the expiration of the applicable warranty period. This limitation is in lieu of any other applicable statute of limitations. **CUSTOMER FURTHER ACKNOWLEDGES AND AGREES THAT THESE WARRANTIES ARE JCI'S SOLE WARRANTIES AND TO THE MAXIMUM EXTENT PERMITTED UNDER APPLICABLE LAW ARE IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THOSE OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.** JCI makes no and specifically disclaims all representations or warranties that the services, products, software or third party product or software will be secure from cyber threats, hacking or other similar malicious activity.

F. CUSTOMER OBLIGATIONS AND COMMITMENTS TO JCI

1. Customer warrants it has given JCI all information concerning the condition of the Covered Equipment. The Customer agrees and warrants that, during the Term of this Agreement, Customer will:

(1) operate the Covered Equipment according to the manufacturer's and/or JCI's recommendations;

(2) keep accurate and current work logs and information about the Covered Equipment as recommended by the manufacturer and/or JCI;

(3) provide an adequate environment for Covered Equipment as recommended by the manufacturer and/or JCI, including, but not limited to adequate space, electrical power, water supply, air conditioning, and humidity control;

(4) notify JCI immediately of any Covered Equipment malfunction, breakdown, or other condition affecting the operation of the Covered Equipment;

(5) provide JCI with safe access to its Premises and Covered Equipment at all reasonable and necessary times for the performance of the Services;

(6) allow JCI to start and stop, periodically turn off, or otherwise change or temporarily suspend equipment operations so that JCI can perform the Services required under this Agreement;

(7) as applicable, provide proper condenser, cooling tower and boiler water treatment for the proper functioning of Covered Equipment and protect against any environmental issues and instances of biohazards such as but not limited to Legionella;

(8) carefully and properly set and test the intrusion alarm system each night or at such other time as Customer shall close the Premises;

(9) obtain all necessary licenses and permits required for and pay all taxes associated with the Services;

(10) notify JCI immediately of any claimed inadequacy in, or failure of, the Covered Equipment or other condition affecting the operation of the Covered Equipment;

(11) furnish any necessary 110 volt A/C power and electrical outlets at its expense;

(12) properly maintain, repair, service, and assure the proper operation of any other property, system, equipment, or device of Customer or others to which the Covered Equipment may be attached or connected, in accordance with manufacturer recommendations, insurance carrier requirements, or the requirements of any fire rating bureau, agency, or other authorities having jurisdiction thereof;

(13) not tamper with, alter, adjust, disturb, injure, remove, or otherwise interfere with any Covered Equipment (including any related software) and not permit the same to be done; and

(14) refrain from causing false alarms, and reimburse JCI for any fine, penalty, or fee paid by or assessed against JCI by any governmental or municipal agency as a result thereof.

(15) be solely responsible for the establishment, operation, maintenance, access, security and other aspects of its computer network ("Network") and shall supply JCI secure Network access for providing its services. Products networked, connected to the internet, or otherwise connected to computers or other devices must be appropriately protected by Customer and/or end user against unauthorized access.

(16) take appropriate measures, including performing back-ups, to protect information, including without limit data, software, or files

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other medium) without the express written permission of Johnson Controls, Inc.

(collectively "Data") prior to receiving the service or products

2. Customer acknowledges and understands that unless water treatment for biohazards (such as Legionella) is expl citly included in the services JCI is providing, it is Customer's responsibility to provide such treatment. Customer also acknowledges that its failure to meet the above obligations will relieve JCI of any responsibility for any Covered Equipment breakdown, or any necessary repair or replacement of any Covered Equipment. If Customer breaches any of these obligations, JCI shall have the right, upon written notice to Customer, to suspend its Services until Customer cures such breach In addition, Customer shall be responsible for paying or reimbursing JCI for any costs associated with corrective work required as a result of Customer's breach of these obl gations.

G. INSURANCE

Customer is responsible for obtaining all insurance coverage that Customer believes is necessary to protect Customer, Customer's property, and persons in or on the Premises, including coverage for personal injury and property damage. **THE PAYMENTS CUSTOMER MAKES UNDER THIS AGREEMENT ARE NOT RELATED TO THE VALUE OF THE PREMISES, CUSTOMER'S PROPERTY OR POSSESSIONS, OR THE PERSONS OCCUPYING OR AT ANY TIME PRESENT IN OR ON THE PREMISES, BUT RATHER ARE BASED ON THE COST OF THE SYSTEM AND THE SERVICES, AND TAKE INTO CONSIDERATION THE PROTECTION AFFORDED TO JCI UNDER THIS AGREEMENT.** Customer hereby releases JCI from any liability for any event or condition customarily covered by commercial liability insurance. Customer understands that neither the Services nor the Covered Equipment are designed to reduce, but not eliminate, certain risks. JCI does not guaranty that neither the Services nor Covered Equipment will prevent personal injury, unauthorized entrances or fire and smoke damage to the Premises Customer further agrees that Customer has read and understands the terms and conditions of this Agreement.

H. INDEMNITY

JCI and Customer shall each indemnify the other party and its officers, agents, directors, and employees, from any and all damages, losses, costs and expenses (including reasonable attorneys' fees) arising out of third party claims, demands, or suits for bodily injury (including death) or damage to tangible property to the extent arising out of the negligence or intentional misconduct of the indemnifying party or its employees or agents. Customer expressly agrees that JCI shall be responsible for injury, damage, or loss only to the extent caused directly by JCI's negligence or intent onal misconduct. The obligations of JCI and Customer under this section are further subject to sections I and J below.

I. LIMITATION OF LIABILITY

TO THE MAXIMUM EXTENT PERMITTED BY LAW, IN NO EVENT SHALL JCI AND ITS AFFILIATES AND THEIR RESPECTIVE PERSONNEL, SUPPLIERS AND VENDORS ("JCI PARTIES") BE LIABLE TO YOU OR ANY THIRD PARTY UNDER ANY CAUSE OF ACTION OR THEORY OF LIABILITY EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, FOR ANY: (1) SPECIAL, INCIDENTAL, CONSEQUENTIAL, PUNITIVE, OR INDIRECT DAMAGES; (2) LOST PROFITS, REVENUES, DATA, CUSTOMER OPPORTUNITIES, BUSINESS, ANTICIPATED SAVINGS, OR GOODWILL; (3) BUSINESS INTERRUPTION; OR (4) DATA LOSS OR OTHER LOSSES ARISING FROM VIRUSES, RANSOMWARE, CYBER ATTACKS OR FAILURES OR INTERRUPTIONS TO NETWORK SYSTEMS. IN ANY CASE, THE ENTIRE AGGREGATE LIABILITY OF THE JCI PARTIES UNDER THIS AGREEMENT FOR ALL DAMAGES, LOSSES, AND CAUSES OF ACTION, WHETHER IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR OTHERWISE SHALL BE LIMITED TO $250,000. CUSTOMER UNDERSTANDS THAT JCI IS NOT AN INSURER REGARDING THE WORK OR THE SERVICES. JCI SHALL NOT BE RESPONSIBLE FOR ANY DAMAGE OR LOSS THAT MAY RESULT FROM FIRE SAFETY OR SECURITY EQUIPMENT THAT FAILS TO PERFORM PROPERLY OR FAILS TO PREVENT A CASUALTY OR LOSS

J. FORCE MAJEURE

JCI shall not be responsible for delays, interruptions or failure to perform due to causes beyond its reasonable control, including but not limited to material shortages, acts of god, acts of government agencies; strikes, labor disputes, work stoppages; fires, explosions or casualties, thefts, vandalism, riots, war or civil disobedience/unrest, terrorism, cyber-attacks, viruses, ransomware, failures or interruptions of network systems, data breaches, severe weather and unavailability of parts, materials, or supplies.

K. RESOLUTION OF DISPUTES

If a dispute arises under this Agreement, the parties shall promptly attempt in good faith to resolve such dispute by negotiation In the event the dispute is unable to be resolved, either party shall have the right to initiate arbitration by filing with the American Arbitration Associat on provided no other legal action has been previously filed. Upon filing of the arbitration, the AAA shall have the exclusive jurisdiction over the Dispute. Thus, either party may decide to file an action in a court of competent jurisdiction. If that court filing is the first legal proceeding filed, that court shall have jurisdiction over the Dispute to the exclusion of any arbitration. Arbitration shall be conducted in accordance with the then current arbitration rules of the American Arbitration Association or other arbitration service mutually agreed to by the parties. Arbitration must be completed within sixty (60) days after the Dispute is submitted to arbitration unless the parties mutually agree otherwise. The award rendered by the arbitrator shall be final, and judgment issued by the Arbitrator may be entered in accordance with applicable law in any court having competent jurisdiction. The party prevailing in the arbitration or court proceeding shall be entitled to an award of its reasonable costs, including reasonable attorneys' fees, incurred as a result of the Dispute CUSTOMER MUST BRING ANY CLAIM AGAINST JCI WITHIN ONE (1) YEAR AFTER THE CLAIM AROSE. IF CUSTOMER DOES NOT, CUSTOMER WILL HAVE IRREVOCABLY WAIVED ITS RIGHT TO SUE JCI AND/OR INSTITUTE OTHER PROCEEDINGS, AND JCI SHALL HAVE NO LIABILITY TO CUSTOMER FOR SUCH CLAIM. TIME IS OF THE ESSENCE RELATIVE TO CUSTOMER PURSUING ANY SUCH CLAIM. THE PROVISIONS OF THIS AGREEMENT WHICH APPLY TO ANY CLAIM SHALL REMAIN IN EFFECT EVEN AFTER THE AGREEMENT IS TERMINATED. JCI AND CUSTOMER EACH WAIVE THEIR RIGHT TO A JURY TRIAL.

L. TERMINATION

1. Remote Monitoring Services and Remote Operating Services may be immediately canceled by either party if JCI's Remote Operations Center, connecting wires, or monitoring systems are destroyed by fire or other catastrophe, or where the Premises are so substantially damaged that it is impractical to continue Services.

2. If either party fails to perform any of its obligations under this Agreement, the other party shall provide written notice thereof to the party alleged to be in default. Should the party alleged to be in default fail to respond in writing or take action to cure the alleged default within ten (10) days of receiving such written notice, the notifying party may terminate this Agreement by providing written notice of such termination

3. JCI may terminate this Agreement and discontinue any Services if JCI is unable to obtain or continue to support technologies, equipment or

© 2020 Johnson Controls Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls Inc

component parts that are discontinued, become obsolete or are otherwise not commercially available. JCI will not be liable for any damages or subject to any penalty as a result of any such termination.

4. Upon termination of this Agreement for any reason, Customer shall pay to JCI all undisputed amounts owed through the date of termination within thirty (30) days of such termination. Customer shall also provide JCI w th reasonable access to the Premises to remove the Gateway Device and any other JCI property and to un-program any intrusion, fire, or life safety system, as applicable. Customer shall be liable for all fees, costs, and expenses that JCI may incur in connection with the enforcement of this Agreement, including without limitation, reasonable attorney fees, collection agency fees, and court costs.

5. If the Agreement is for a multi-year term, either party may terminate the Agreement after the first full year of Services by giving the other party no less than forty-five (45) days written notice.

M. ASBESTOS, MOLD, BIOAHAZARDS, AND HAZARDOUS MATERIALS

"Hazardous Materials" means any material or substance that, whether by its nature or use, is now or hereafter defined or regulated as a hazardous waste, hazardous substance, pollutant, or contaminant under any local, state, or federal law, regulation, or ordinance relating to or addressing public and employee health and safety and protection of the environment, or which is toxic, explosive, corrosive, flammable, radioactive, carcinogenic or otherwise hazardous or which is or contains petroleum, gasoline, diesel, fuel, another petroleum hydrocarbon product or polychlorinated biphenyls. "Hazardous Materials" specifically includes mold, lead-based paints, biohazards such as but not limited to Legionella and asbestos-containing materials ("ACM").
Neither Customer nor JCI desires to or is licensed to undertake direct obligations relating to the identification, abatement, cleanup, control, removal or disposal of ACM.

JCI will be responsible for removing or disposing of any Hazardous Materials that it uses in providing the Services ("JCI Hazardous Materials") and for the remediation of any areas affected by the release of JCI Hazardous Materials. For other Hazardous Materials that may be present at its facilities ("Non-JCI Hazardous Materials"), Customer shall supply JCI with any information in its possession relating to the presence of Hazardous Materials if their presence may affect JCI's performance of the Services. If either Customer or JCI becomes aware of or suspects the presence of Non-JCI Hazardous Materials that may interfere with JCI's Services, it shall immediately stop the Services in the affected area and notify the other party. As between Customer and JCI, Customer shall be responsible at its sole expense for removing and disposing of Non-JCI Hazardous Materials from its facilities and for the remediation of any areas impacted by the release of the Non-JCI Hazardous Materials and must provide a certificate of abatement before JCI will be obligated to perform or continue its Services, unless JCI had actual knowledge that Non-JCI Hazardous Materials were present and acted in disregard of that knowledge, in which case (i) JCI shall be responsible at its sole expense for the remediation of any areas impacted by its release of such Hazardous Materials, and (ii) Customer shall remain responsible at its sole expense for the removal of Hazardous Materials that have not been released and for releases not resulting from JCI's performance of the Services. Customer shall defend and indemnify JCI against any losses, costs, damages, expenses, and claims arising out of its failure to comply with this Section M.

N. CUSTOMER DATA

Customer data obtained from the Services is owned by and shall belong to Customer. JCI will access and use Customer data to provide Services to Customer. Except as set forth herein, JCI will not disclose to any third party any individual Customer data acquired through performance of the Services without Customer's consent. Customer agrees that JCI and its subsidiaries, affiliates and approved third party contractors and developers may collect and use Customer data for any reason, as long as any external use of the data is on a de-identified basis that does not personally identify Customer or any individual. Customer hereby grants JCI a perpetual, worldwide, irrevocable, royalty free license to use, modify, manipulate, sublicense, and create derivative works from such data. JCI shall retain all rights to any intellectual property, data, materials and products created as a result of its performance of Services.

O. JCI'S INTELLECTUAL PROPERTY

JCI shall retain all right, title and interest in any (a) work provided to Customer, including without limitation, all software source and object code, documentation, technical information or data, specifications and designs and any changes, improvements or modifications thereto ("Deliverables"), and (b) Know-How (defined below) employed by JCI in the creation of the Deliverables or performance of the Services, whether known to JCI prior to, or developed or discovered or acquired in connection with, the performance of its obligations under this agreement. Ownership of all Deliverables and Know-How shall vest solely in JCI and no Deliverables shall be deemed "works made for hire." Without limiting the generality of the foregoing, ownership of all source files used in the course of performing the Services shall remain the exclusive property of JCI. For purposes of this Agreement, "Know-How" means any know-how, processes, techniques, concepts, methodologies, tools, analytical approaches, database models and designs, discoveries, and ideas furnished, produced by, developed, or used by JCI in the creation or provision of the Deliverables or in the performance of the Services, and any changes, improvements, or modifications thereto or derivatives thereof.

P. DIGITAL TERMS

Any license to or right to access JCI software products and digital or cloud services purchased under this Agreement is provided on the terms and conditions for the applicable software product or digital or cloud service set forth at http://www.johnsoncontrols.com/buildings/legal/digital. Such applicable software product and digital services terms are incorporated by reference herein.

Q. MISCELLANEOUS PROVISIONS

1. All notices required to be given hereunder shall be in writing and shall be considered properly given if: (a) delivered in person, (b) sent via the United States Postal Service, postage prepaid, registered or certified with return receipt requested, (c) sent by overnight delivery service (e.g., FedEx, UPS), or (d) sent by facsimile, email or other electronic means and confirmed by facsimile, return email or telephone.

2. This Agreement may not be assigned by Customer without JCI's prior written consent. JCI shall have the right to assign this Agreement to any other person, firm, or corporation without Customer's consent. JCI shall also have the right, in its sole discretion, to subcontract any portion of the Services. This Agreement inures to the benefit of and is applicable to any assignees or subcontractors of JCI, and is binding upon Customer with respect to said assignees or subcontractors with the same force and effect as it binds Customer to JCI.

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other medium) without the express written permission of Johnson Controls, Inc.

3. This Agreement shall be subject to and governed by the laws of the State where the Services are performed.

4. If any provision of this Agreement is found to be invalid, illegal or unenforceable in any respect, the validity, legality and enforceability of the remaining provisions contained herein shall not in any way be affected or impaired thereby.

5. This Agreement is the entire contract between JCI and Customer and supersedes any prior oral understandings, written agreements, proposals, or other communications between the parties.

6. Customer acknowledges and agrees that any purchase order issued by Customer in connection with this Agreement is intended only to establish payment authority for Customer's internal accounting purposes and shall not be considered to be a counteroffer, amendment, modification, or other revision to the terms of this Agreement. No term or condition included or referenced in Customer's purchase order will have any force or effect and these terms and conditions shall control. Customer's acceptance of any Services shall constitute an acceptance of these terms and conditions. Any proposal for additional or different terms, whether in Customer's purchase order or any other document, unless expressly accepted in writing by JCI, is hereby objected to and rejected.

7. If there are any changes to Customer's facilities or operations, or to applicable regulations, laws, codes, taxes, or utility charges, that materially affect JCI's performance of the Services or its pricing thereof, JCI shall have the right to an equitable and appropriate adjustment to the scope, pricing, and other affected terms of this Agreement.

8. No claim or cause of action, whether known or unknown, shall be brought against JCI more than one year after the claim first arose. Except as provided for herein, JCI's claims must also be brought within one year. Claims for unpaid contract amounts are not subject to the one-year limitation.

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

ADDENDUM TO PSA TERMS AND CONDITIONS FOR MONITORING OF INTRUSION, FIRE AND OTHER SAFETY SYSTEMS

If Remote Monitoring Services explicitly includes remote fire alarm monitoring, security alarm monitoring or video monitoring in the scope of work or customer charges, the Agreement is hereby modified and amended to include the terms and provisions of this Addendum to the PSA for Monitoring of Intrusion, Fire and Safety Systems (the "Addendum"). Capitalized terms that are not defined herein, shall have the meaning given to them in the Agreement. In the event of a conflict between the terms and conditions of this Addendum and those appearing in the Agreement, the terms and conditions of this Addendum shall prevail.

1. **Remote Monitoring of Alarm Signals.** If JCI receives an emergency alarm signal at JCI's ROC, JCI shall endeavor to notify the appropriate police or fire department, or other emergency response agency having jurisdiction and JCI shall endeavor to notify Customer or its designated representative by email unless instructed to do otherwise by Customer in writing and/or based on standard operating procedures for the ROC. JCI, upon receipt of a non-emergency signal from the Premises, shall endeavor to notify Customer's representative pursuant to Customer's written instructions, defaulting to email or text notification. Customer acknowledges that if the signals transmitted from the Premises will be monitored in a monitoring facility not operated by JCI, the personnel in such monitoring facilities are not the agents of JCI, nor does JCI assume any responsibility for the manner in which such signals are monitored or the response to such signal

2. **Remote Monitoring Services Pricing.** Remote Monitoring Services shall be provided by JCI if the Agreement includes a charge for such Service. If such Service is purchased, JCI will monitor the number of alarms for the Premises and the initial charge is based on the pricing agreed to by the parties, subject to the terms and conditions of this Addendum. If the number of alarms produced at the Premises goes beyond the contracted number of alarms in a month, Customer will be billed an overage fee.

3. **Communications Media.** Customer acknowledges that monitoring of Covered Equipment requires transmission of signals over standard telephone lines and/or the Internet and that these modes of transmission may be interrupted, circumvented, or compromised, in which case no signal can be transmitted from the Premises to the monitoring facility. Customer understands that to allow the monitoring facility to be aware of such a condition, additional or alternative protection can be installed, such as line security devices, at Customer's cost and expense and for transmission via telephone line only. Customer acknowledges it is aware that line security devices are available and, unless expressly identified in Schedule A - Equipment List, has declined to purchase such devices. Customer further acknowledges that such additional protection is not available for Internet transmission under this Agreement.

4. **False/Unnecessary Alarms; Service Calls.** At JCI's option, an additional fee may be charged for any false alarm or unnecessary Service Visit caused or necessitated by Customer. In addition, Customer shall be fully responsible and liable for fines, penalties, assessments, taxes, fees or charges imposed by a governmental body, telephone, communication, or signal transmission company as the result of any false alarm and shall reimburse JCI for any costs incurred by JCI in connection therewith. Customer shall operate the system carefully so as to avoid causing false alarms. False alarms can be caused by severe weather or other forces beyond the control of JCI. If an undue number of false alarms are received by JCI, in addition to any other available remedies available to JCI, JCI may terminate this Agreement and discontinue any Service(s) and seek to recover damages. If an agent is dispatched, by a governmental authority or otherwise, to respond to a false alarm, where the Customer, or any other party has intentionally, accidentally or negligently activated the alarm signal, Customer shall be responsible for and pay any and all fees and/or fines assessed with respect to the false alarms and pay to JCI the additional charges and costs incurred by it from a false alarm. If the Customer's system has a local audible device, Customer authorizes JCI to enter the Premises to turn off the audible device if JCI is requested or ordered to do so by governmental authorities, neighbors or anyone else and Customer will pay JCI its standard service call charge for each such visit. Police agencies require repair of systems which cause false dispatches. Customer shall maintain the equipment necessary for JCI to supply the Services and Customer shall pay all costs for such maintenance. At least monthly, Customer will test the system's protective devices and send test signals to the ROC for all monitoring equipment in accordance with instructions from JCI or the ROC. Customer agrees to test the monitoring systems, including testing any ultrasonic, microwave, infrared, capacitance or other electronic equipment prior to the end of each month and will immediately report to JCI if the equipment fails to respond to the test. Customer shall make any necessary repairs as soon after receipt of notice as is reasonably practical. Customer shall at all times be solely responsible for maintaining any sprinkler system in good working order and provide adequate heat to the Premises

5. **Remote Monitoring of Video Monitoring Services.** During the Term, JCI's sole and only obligation arising from the inclusion of Video Monitoring Services in any Service offering shall be to monitor the digital signals actually received by JCI at its ROC from means of the Video System and upon receipt of a digital signal indicating that an alarm condition exists, to endeavor, as permitted by law, to notify the police or other municipal authority deemed appropriate in JCI's absolute discretion and to such persons Customer has designated in writing to JCI to receive notification of such alarm condition as set forth herein. . No alarm installation, repair, maintenance or guard responses will be provided under this Video Monitoring Services option. JCI may, without prior notice to Customer, in response to applicable law or insurance requirements, revise, replace, discontinue and/or rescind its response policies and procedures.

   a. **Inception and conclusion of service.** Video Monitoring shall be provided by JCI if this Agreement includes a charge for Video Monitoring Services. If such Video Monitoring Service is purchased, Video Monitoring Services will begin when the Video System is installed and operational, and when the necessary communications connection is completed. No obligation for the provision of this Video Monitoring Service will commence until these requirements are met.

   b. **Customer Equipment.** Customer shall obtain, at its own cost and expense: (a) the equipment necessary to connect to JCI's ROC, and (b) whatever permission, permits or licenses that may be necessary from all persons, governmental authorities, utility, and any other related service providers in connection with the Services. The video system to be used by the Customer is intended to produce and transmit video images (the "Video System Images") of the Premises to the ROC (the "Video System"). JCI makes no promise, warranty or representation that the video system will operate as intended. Customer further agrees that, notwithstanding any role or participation by JCI in Video System and Video System Images, JCI shall have no responsibility or obligation with regard to Customer, the Video System or any other Customer equipment

   c. **System Location.** The Video System related cameras shall be located and positioned by Customer along with attendant burglary digital alarm signal(s). Customer shall ensure that the Video System related cameras will be positioned and located such that it will only produce or

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

capture Video System Images of areas of the Premises. Customer will provide adequate illumination under all operating conditions for the proper viewing of the cameras. Customer acknowledges and agrees that JCI has exercised no control over, or participated in locating or positioning the Video System related camera including, but not limited to selecting what areas, locations, things or persons that the Video System Images may depict or capture.

d. **Images.** Customer shall be solely responsible for the Video System Images produced or captured by the Video System and Customer shall defend, indemnify and hold harmless JCI and its officers, agents, directors, and employees, from any and all damages, losses, costs and expenses (including reasonable attorneys' fees) arising out of third party claims, demands, or suits in connection with the use, operation, location and position of the Video System, and the Video System Images resulting there from, including, but not limited to, any claims of any person depicted in a Video System image, including but not limited to, any claim by such person that his or her privacy has been invaded or intruded upon or his or her likeness has been misappropriated. Any duty to obtain the consent or permission of any person depicted in a Video System Image to have his or her likeness to be depicted, received, transmitted or otherwise used, and the duty to determine and comply with any and all applicable laws, regulations, standards and other obligations that govern the legal, proper and ethical use of video capturing devices, such as the Video System, including, but not limited to, notification that the Video System is in use at the Premises, shall be the sole responsibility of the Customer. JCI agrees to make Video System Images available to Customer and upon their respective request. JCI makes no promise, warranty or representation as to the length of time that it retains Video Images, or the quality thereof.

e. **Video System Signals.** When a signal from the Video System is received, JCI reserves the right to verify all alarm signals before notifying emergency personnel, and may choose not to notify emergency personnel if it has reason to believe, in its sole discretion, that an emergency condition does not exist. JCI will first attempt to verify the nature of the emergency by using visual verification and/or the two-way voice system (if applicable) of the Video System included in Customer's system. If JCI determines that an emergency condition exists, JCI will endeavor to notify the proper police or emergency contact on a notification call list provided in writing by Customer to JCI, or its designee. When a non-emergency signal is received, JCI will attempt to contact the first available Customer representative on the notification call list but will not notify emergency authorities, this notification will be in the form of email or text and follow ROC processes. If the customer requires phone calls to the call list for any emergency or non-emergency situation, the customer will need to make this request in writing. Customer authorizes and directs JCI, as its agent, to use its full discretion in causing the arrest or detention of any person or persons on or around the premises who are not authorized by Customer. **JCI WILL NOT ARREST OR DETAIN ANY PERSON.**

f. **Recordings.** Customer consents to the tape recording of all telephonic communications between the Premises and JCI. JCI will have no liability arising from recording (or failure to record) or publication of any two-way voice communications, other video recordings or their quality. JCI shall have no liability in connection with Video System or the Video System Images, including, but not limited to, any failure, omission, negligence or other act by JCI, or any of its officers, employees, representatives, agents, contractors, or any other third party in connection with the receipt (or failure of receipt), transmission, reading, interpreting, or response to any Video Image.

6. **Risk of Loss is Customer's.** JCI does not represent or warrant that the Services will prevent any loss by burglary, holdup, fire or otherwise, or that the Services will in all cases provide the protection for which it is installed or intended, or that the Services will be uninterrupted or error-free. Customer assumes all risk of loss or damage to the Premises being monitored and to its contents, whether belonging to Customer or others, and has not relied on any representations and warranties of JCI, express or implied, except as specifically set forth in this Agreement. Further, expressly excluded from this Agreement are the warranties of merchantability or fitness or suitability for a particular purpose.

7. **JCI'S RECEIPT OF ALARM SIGNALS, ELECTRONIC DATA, VOICE DATA OR IMAGES (COLLECTIVELY, "ALARM SIGNALS") FROM THE EQUIPMENT OR SYSTEM INSTALLED IN THE PREMISES IS DEPENDENT UPON PROPER TRANSMISSION OF SUCH ALARM SIGNALS. JCI'S ROC CANNOT RECEIVE ALARM SIGNALS WHEN THE CUSTOMER'S TELCO SERVICE OR OTHER TRANSMISSION MODE IS NOT OPERATING OR HAS BEEN CUT, INTERFERED WITH, OR IS OTHERWISE DAMAGED, OR IF THE ALARM SYSTEM IS UNABLE TO ACQUIRE, TRANSMIT OR MAINTAIN AN ALARM SIGNAL OVER CUSTOMER'S TELCO SERVICE OR TRANSMISSION MODE FOR ANY REASON INCLUDING BUT NOT LIMITED TO NETWORK OUTAGE OR OTHER NETWORK PROBLEMS SUCH AS CONGESTION OR DOWNTIME, ROUTING PROBLEMS, OR INSTABILITY OF SIGNAL QUALITY. CUSTOMER UNDERSTANDS THAT SIGNAL TRANSMISSION FAILURE MAY OCCUR OVER CERTAIN TYPES OF TELCO SERVICES SUCH AS SOME TYPES OF DSL, ADSL, VOIP, DIGITAL PHONE, INTERNET PROTOCOL BASED PHONE OR OTHER INTERNET INTERFACE-TYPE SERVICE OR RADIO SERVICE, INCLUDING CELLULAR, WIRELESS OR PRIVATE RADIO, OR CUSTOMER'S PROPRIETARY TELCOMMUNICATION NETWORK, INTRANET OR IP-PBX, OR OTHER THIRD-PARTY EQUIPMENT OR VOICE/DATA TRANSMISSION NETWORKS OR SYSTEMS OWNED, MAINTAINED OR SERVICED BY CUSTOMER OR THIRD PARTIES, IF: (1) THERE IS A LOSS OF NORMAL ELECTRIC POWER TO THE MONITORED PREMISES OCCURS (THE BATTERY BACK-UP FOR JCI'S ALARM PANEL DOES NOT POWER CUSTOMER'S COMMUNICATION FACILITIES OR TELCO SERVICE); OR (2) ELECTRONIC COMPONENTS SUCH AS MODEMS MALFUNCTION OR FAIL. CUSTOMER UNDERSTANDS THAT JCI WILL ONLY REVIEW THE INITIAL COMPATIBILITY OF THE ALARM SYSTEM WITH CUSTOMER'S TELCO SERVICE AT THE TIME OF INITIAL INSTALLATION OF THE ALARM SYSTEM AND THAT CHANGES IN THE TELCO SERVICE'S DATA FORMAT AFTER JCI'S INITIAL REVIEW OF COMPATIBILITY COULD MAKE THE TELCO SERVICE UNABLE TO TRANSMIT ALARM SIGNALS TO JCI'S ROC. IF JCI DETERMINES IN ITS SOLE DISCRETION THAT CUSTOMER'S TELCO SERVICE IS COMPATIBLE, JCI WILL PERMIT CUSTOMER TO USE ITS TELCO SERVICE AS THE PRIMARY METHOD OF TRANSMITTING ALARM SIGNALS, ALTHOUGH CUSTOMER UNDERSTANDS THAT JCI RECOMMENDS THAT CUSTOMER ALSO USE AN ADDITIONAL BACK-UP METHOD OF COMMUNICATION TO CONNECT CUSTOMER'S ALARM SYSTEM TO JCI'S ROC REGARDLESS OF THE TYPE OF TELCO SERVICE USED. CUSTOMER ALSO UNDERSTANDS THAT IF JCI DETERMINES IN ITS SOLE DISCRETION THAT CUSTOMER'S TELCO SERVICE IS, OR LATER BECOMES, NON-COMPATIBLE, OR IF CUSTOMER CHANGES TO ANOTHER TELCO SERVICE THAT IS NOT COMPATIBLE, THEN JCI WILL REQUIRE THAT CUSTOMER USE AN ALTERNATE METHOD OF COMMUNICATION ACCEPTABLE TO JCI AS THE PRIMARY METHOD TO CONNECT CUSTOMER'S ALARM SYSTEM TO JCI'S ROC. JCI WILL NOT PROVIDE FIRE OR SMOKE ALARM MONITORING FOR CUSTOMER BY MEANS OTHER THAN AN APPROVED TELCO SERVICE AND CUSTOMER UNDERSTANDS THAT IT IS SOLELY RESPONSIBLE FOR ASSURING THAT IT USES APPROVED TELCO SERVICE FOR ANY SUCH MONITORING AND THAT IT COMPLIES WITH NATIONAL FIRE ALARM STANDARDS AND LOCAL FIRE CODES. CUSTOMER ALSO UNDERSTANDS THAT IF CUSTOMER'S ALARM SYSTEM HAS A LINE CUT FEATURE, IT MAY NOT BE ABLE TO DETECT ALARM SIGNALS IF THE TELCO SERVICE IS INTERRUPTED, AND THAT JCI MAY NOT BE ABLE TO DOWNLOAD SYSTEM CHANGES REMOTELY OR PROVIDE CERTAIN AUXILIARY MONITORING SERVICES THROUGH A NON-APPROVED TELCO SERVICE. CUSTOMER ACKNOWLEDGES THAT ANY DECISION TO USE A NON-APPROVED TELCO SERVICE AS THE METHOD FOR TRANSMITTING ALARM SIGNALS IS BASED ON CUSTOMER'S OWN INDEPENDENT BUSINESS JUDGMENT AND THAT ANY SUCH DECISION IS MADE WITHOUT ANY ASSISTANCE, INVOLVEMENT, INPUT, RECOMMENDATION, OR ENDORSEMENT ON THE PART OF JCI. CUSTOMER ASSUMES SOLE AND COMPLETE RESPONSIBILITY FOR ESTABLISHING AND MAINTAINING ACCESS TO AND USE OF**

© 2020 Johnson Controls, Inc.
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc.

THE NON-APPROVED TELCO SERVICE FOR CONNECTION TO THE ALARM MONITORING EQUIPMENT. CUSTOMER FURTHER UNDERSTANDS THAT THE ALARM SYSTEM MAY BE UNABLE TO SEIZE THE TELCO SERVICE TO TRANSMIT AN ALARM SIGNAL IF ANOTHER CONNECTION HAS DISABLED, IS INTERFERING WITH, OR BLOCKING THE CONNECTION.

[END OF DOCUMENT]

© 2020 Johnson Controls, Inc
Customer Confidential
Do not copy (physically, electronically, or in any other media) without the express written permission of Johnson Controls, Inc

ACORD

CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
01/08/2020

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER
Marsh USA Inc.
411 E. Wisconsin Avenue
Suite 1300
Milwaukee, WI 53202
Attn: JCI Certrequest@marsh.com
CN101230596-5-19-20*

CONTACT NAME:
PHONE (A/C, No, Ext):
FAX (A/C, No):
E-MAIL ADDRESS:

INSURER(S) AFFORDING COVERAGE	NAIC #
INSURER A : Old Republic Insurance Company	24147
INSURER B : ACE Property and Casualty Insurance Company	20699
INSURER C :	
INSURER D :	
INSURER E :	
INSURER F :	

INSURED
Johnson Controls, Inc.
Tyco International Holding S a r.l
SimplexGrinnell LP
(see attached Acord 101)
5757 North Green Bay Avenue
Milwaukee, WI 53209

COVERAGES

CERTIFICATE NUMBER: CHI-008734238-06

REVISION NUMBER: 5

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL INSD	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS	
A	X COMMERCIAL GENERAL LIABILITY			MWZY 313947-19	10/01/2019	10/01/2020	EACH OCCURRENCE	$ 10,000,000
	CLAIMS-MADE X OCCUR						DAMAGE TO RENTED PREMISES (Ea occurrence)	$ 10,000,000
	X Contractual Liability						MED EXP (Any one person)	$ 50,000
	X XCU Included						PERSONAL & ADV INJURY	$ 10,000,000
	GEN'L AGGREGATE LIMIT APPLIES PER:						GENERAL AGGREGATE	$ 30,000,000
	X POLICY PRO-JECT LOC						PRODUCTS - COMP/OP AGG	$ INC IN GEN AGG
	OTHER:							$
A	AUTOMOBILE LIABILITY			MWTB 313946-19 (Excludes New Hamp)	10/01/2019	10/01/2020	COMBINED SINGLE LIMIT (Ea accident)	$ 7,500,000
A	X ANY AUTO			MWTB 313949-19 (Primary NH $250k)	10/01/2019	10/01/2020	BODILY INJURY (Per person)	$
A	OWNED AUTOS ONLY / SCHEDULED AUTOS			MWZX 313950-19 (Excess NH $7.25mm)	10/01/2019	10/01/2020	BODILY INJURY (Per accident)	$
	HIRED AUTOS ONLY / NON-OWNED AUTOS ONLY			Excess NH Auto is Follow Form			PROPERTY DAMAGE (Per accident)	$
				to Primary NH Auto				$
B	X UMBRELLA LIAB X OCCUR			G28162509 004	10/01/2019	10/01/2020	EACH OCCURRENCE	$ 5,000,000
	X EXCESS LIAB CLAIMS-MADE						AGGREGATE	$ 5,000,000
	DED RETENTION $							$
A	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY			MWC 313943-19 (AOS - see page 2)	10/01/2019	10/01/2020	X PER STATUTE OTH-ER	
A	ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) Y/N N	N/A		MWXS 313944 (OH & WA)	10/01/2019	10/01/2020	E.L. EACH ACCIDENT	$ 5,000,000
	If yes, describe under DESCRIPTION OF OPERATIONS below						E.L. DISEASE - EA EMPLOYEE	$ 5,000,000
							E.L. DISEASE - POLICY LIMIT	$ 5,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)
City of Jacksonville, its members, officials, officers, employees and agents are included as additional insured per the attached.

See attached Acord 101 for additional information including Additional Insured, Primary/Non-contributory, Waiver of Subrogation and Notice of Cancellation provisions.

CERTIFICATE HOLDER

City of Jacksonville
Public Buildings Division
555 West 44th Street
Jacksonville, FL 32208

CANCELLATION

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE
of Marsh USA Inc.

Manashi Mukherjee

© 1988-2016 ACORD CORPORATION. All rights reserved.

The ACORD name and logo are registered marks of ACORD

AGENCY CUSTOMER ID: CN101230596
LOC #: Milwaukee

ADDITIONAL REMARKS SCHEDULE

AGENCY		NAMED INSURED
Marsh USA Inc.		Johnson Controls Inc. Tyco International Holding S.a.r.l. SimplexGrinnell LP (see attached Acord 101) 5757 North Green Bay Avenue Milwaukee, WI 53209
POLICY NUMBER		
CARRIER	NAIC CODE	EFFECTIVE DATE:

ADDITIONAL REMARKS

THIS ADDITIONAL REMARKS FORM IS A SCHEDULE TO ACORD FORM,
FORM NUMBER: 25 FORM TITLE: Certificate of Liability Insurance

WORKERS COMPENSATION:
Workers Compensation "AOS" Policy includes coverage for employees from the following States WHILE WORKING IN ANY STATE:AK, AL, AR, AZ, CA, CO, CT, DC, DE, FL, GA, HI, IA, ID, IL, IN, KS, KY, LA, MA, MD, ME, MI, MN, MO, MS, MT, NC, NE, NH, NJ, NM, NV, NY, OK, OR, PA, RI, SC, SD, TN, TX, UT, VA, VT, WI, & WV.

PRIMARY COVERAGE:
The General Liability and Automobile Liability policies are primary and not excess of or contributing with other insurance or self-insurance, where required by written lease or written contract. For General Liability, this applies to both ongoing and completed operations.

WAIVER OF SUBROGATION:
The General Liability, Automobile Liability, Workers' Compensation and Employers Liability policies include a Waiver of Subrogation in favor of the certholder and any other person or organization, BUT ONLY to the extent required by written contract.

ADDITIONAL INSURED - AUTOMOBILE LIABILITY:
The Automobile Liability policy, if required by written contract, includes coverage for Additional Insureds as required by such written contract.

ADDITIONAL INSURED - GENERAL LIABILITY:
For General Liability, if required by written contract, the following are included as additional insureds, as required pursuant to a written contract with a named insured, per attached Policy Endorsements A2 and A2A: THE CERTIFICATE HOLDER LISTED ON THIS CERTIFICATE OF LIABILITY INSURANCE, AND EACH OTHER PERSON OR ORGANIZATION REQUIRED TO BE INCLUDED AS AN ADDITIONAL INSURED PURSUANT TO A WRITTEN CONTRACT WITH THE NAMED INSURED.

ONGOING OPERATIONS AND COMPLETED OPERATIONS INSURANCE
The General Liability Insurance includes insurance for ongoing operations and completed operations.

LIMIT OF LIABILITY:
The Liability Limit that applies is the amount indicated on the face of this Certificate of Liability Insurance, or the minimum Liability limit that is required by the written contract, whichever is less. If there is no contract then the Liability Limit is limited to $1,000,000.

UMBRELLA/EXCESS LIABILITY
If the primary insurance policies noted on the face of this Certificate of Liability Insurance satisfy the combination of minimum primary limits and minimum Umbrella/Excess Liability limits required by the written contract, the Umbrella/Excess Liability limits shown on the face of this Certificate of Liability Insurance do not apply.

NOTICE OF CANCELLATION TO CERTIFICATE HOLDERS:
Should any of the above described policies be cancelled, other than for non-payment, before the expiration date thereof, 30 days advice of cancellation will be delivered to certificate holders in accordance with the policy endorsements.

NAMED INSURED:
Air Distribution Technologies IP, LLC; Air System Components, Inc.; Carter Brothers, LLC; CEM Access Systems, Inc.; Central CPVC Corporation; Central Sprinkler LLC, Chemguard, Inc., Connect 24 Wireless Communications Inc.; Digital Security Controls, Inc.; Eastern Sheet Metal, Inc.; Elpas, Inc., Exacq Technologies, Inc., FBN Transportation, Inc., Federal Energy Infrastructure Solutions, LLC; Grinnell Fire Protection Solutions LLC; Grinnell LLC; Hart & Cooley Trucking Company; Hart & Cooley, Inc., Haz-Tank Fabricators, Inc., IMECO LLC; Integrated Systems and Power, Inc.; Johnson Controls (Suisse) SA, Johnson Controls Air Conditioning and Refrigeration, Inc., Johnson Controls Building Automation Systems, LLC; Johnson Controls Digital Solutions LLC; Johnson Controls Engineering, LLC, Johnson Controls Federal Systems, Inc., Johnson Controls Fire Protection LP; Johnson Controls Foundation, Inc.; Johnson Controls Government Systems, LLC; Johnson Controls, Inc.; Johnson Controls Navy Systems, LLC; Johnson Controls PI Project Site Operations LLC; Johnson Controls Security Solutions LLC; Johnson Controls-Hitchi Air Conditioning North America LLC, Koch Filter Corporation; Master Protection LP dba FireMaster; Qolsys, Inc., Retail Expert, Inc.; Ruskin Company; Ruskin Rooftop Systems, Inc.; Ruskin Service Company; Selkirk Corporation; Senelco Iberia, Inc., Sensormatic Asia/Pacific, Inc., Sensormatic Electronics (Puerto Rico) LLC; Sensormatic Electronics, LLC; ShopperTrak International Investment LLC, ShopperTrak RCT Corporation; Shurjoint America, Inc., SimplexGrinnell LP; Tyco Fire & Security LLC; Tyco Fire Products LP; Tyco Integrated Security LLC, Tyco International Holding S.a r.l., Tyco International Management Company, LLC, Visonic Inc.; WitFire HC, LLC, York International (SA), Inc.; York International Corporation

© 2008 ACORD CORPORATION. All rights reserved.
The ACORD name and logo are registered marks of ACORD

IL 10 (12/06) OLD REPUBLIC INSURANCE COMPANY

ADDITIONAL INSURED - OWNERS, LESSEES OR CONTRACTORS - SCHEDULED PERSON OR ORGANIZATION - ENDORSEMENT A2

Named Insured Johnson Controls, Inc. Tyco International Holding S.a.r.l.			Endorsement Number
Policy Prefix MWZY	Policy Number 313947 19	Policy Period 10/01/2019 - 10/01/2020	Effective Date of Endorsement 10/01/19
Issued By Old Republic Insurance Company			

THIS ENDORSEMENT CHANGES THE POLICY. PLEASE READ IT CAREFULLY.

This endorsement modifies insurance provided under the following:

COMMERCIAL GENERAL LIABILITY COVERAGE PART

SCHEDULE

Name Of Additional Insured Person(s) Or Organization(s):

If required by contract, the person or organization listed on the certificate of insurance as additional insured, and each other person or organization required to be included as an additional insured pursuant to a contract with a named insured.

Location(s) Of Covered Operations:

As required by contract.

Information required to complete this Schedule, if not shown above, will be shown in the Declarations.

A. **Section II - Who Is An Insured** is amended to include as an additional insured the person(s) or organization(s) shown in the Schedule, but only with respect to liability for "bodily injury", "property damage" or "personal and advertising injury" caused solely by:

1. Your acts or omissions; or

2. The acts or omissions of those acting on your behalf;

in the performance of your ongoing operations for the additional insured(s) at the location(s) designated above.

B. With respect to the insurance afforded to these additional insureds, the following additional exclusions apply:

This insurance does not apply to "bodily injury" or "property damage" occurring after:

1. All work, including materials, parts or equipment furnished in connection with such work, on the project (other than service, maintenance or repairs) to be performed by or on behalf of the additional insured(s) at the location of the covered operations has been completed; or

2. That portion of "your work" out of which the injury or damage arises has been put to its intended use by any person or organization other than another contractor or subcontractor engaged in performing operations for a principal as a part of the same project.

GL 289 001 1012

IL 10 (12/06) OLD REPUBLIC INSURANCE COMPANY

ADDITIONAL INSURED - OWNERS, LESSEES OR CONTRACTORS - COMPLETED OPERATIONS - ENDORSEMENT A2A

Named Insured Johnson Controls, Inc. Tyco International Holding S.a.r.l.			Endorsement Number
Policy Prefix MWZY	Policy Number 313947 19	Policy Period 10/01/2019 - 10/01/2020	Effective Date of Endorsement 10/01/19
Issued By Old Republic Insurance Company			

THIS ENDORSEMENT CHANGES THE POLICY. PLEASE READ IT CAREFULLY.

This endorsement modifies insurance provided under the following:

COMMERCIAL GENERAL LIABILITY COVERAGE PART

SCHEDULE

Name Of Additional Insured Person(s) Or Organization(s):

If required by contract, the person or organization listed on the certificate of insurance as additional insured, and each other person or organization required to be included as an additional insured pursuant to a contract with a named insured.

Location And Description Of Completed Operations:

As required by contract

Information required to complete this Schedule, if not shown above, will be shown in the Declarations.

Section II - Who Is An Insured is amended to include as an additional insured the person(s) or organization(s) shown in the Schedule, but only with respect to liability for "bodily injury" or "property damage" caused solely by "your work" at the location designated and described in the Schedule of this endorsement performed for that additional insured and included in the "products-completed operations hazard".

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 **OPEN DATE:**

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to increase piggyback award with Johnson Controls, Inc. (contract #9572-04), to add funding in the amount of $1,000,000.00 for as needed HVAC Equipment, Installation and Facility Services. Total revised award amount not-to-exceed $3,850,416.01.

This award is to be funded by various accounts and executed by contract amendment through Office of General Counsel and processed by individual releases against the master blanket.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: Marilyn Laidler
MARILYN LAIDLER

RESPECTFULLY SUBMITTED
GREGORY PEASE, CHIEF
PROCUREMENT DIVISION

CONCURRENCE BY: Roy Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING 0 DATE: 10/24/19

Teresa R. Eilman _____ OTHER: _____

_____ _____

_____ _____

ACTION OF AWARDING AUTHORITY DATE 10/24/19

APPROVED ✓ BH DISAPPROVED _____

OTHER _____

SIGNATURE OF AUTHENTICATION _____

Brian Hughes
Chief Administrative Officer
For: Mayor Lenny Curry
Under Authority of:
Executive Order No: 2019-02

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to increase piggyback award with Johnson Controls, Inc. (contract #9572-04), to add funding in the amount of $1,500,000.00 for as needed HVAC Equipment, Installation and Facility Services. Total revised award amount not-to-exceed $2,850,416.01.

This award is to be funded by various accounts and executed by contract amendment through Office of General Counsel and processed by individual releases against the master blanket.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: MARILYN LAIDLER RESPECTFULLY SUBMITTED GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Roy Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE: 4/25/19

OTHER:

ACTION OF AWARDING AUTHORITY DATE 4/25/19

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Mousa
Chief Administrative Officer
For: Mayor Lenny Curry
Under Authority of
Executive Order No. 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to utilize first renewal with Johnson Controls, Inc. (contract #9572-04), for piggyback GSA Contract #GS-07F-190CA, to include inspections and preventative maintenance along with scheduled service materials on Chiller and Chiller related equipment. The annual cost for Year 2 will be $60,906.00 ($5,075.00 per month). Period of service will be from February 1, 2019 through January 31, 2020; Year 3 (02/01/20-08/31/20) will be awarded at a later date. Total award remains unchanged at 1,350,416.01.

This award is to be executed by contract amendment through Office of General Counsel, no additional funding being encumbered.

Attachments: Recommendation Memo, Vendor Proposal, Current Certificate of Insurance, Previous Award(s)

BUYER: Marilyn Laidler RESPECTFULLY SUBMITTED
MARILYN LAIDLER
GREGORY PEASE, CHIEF
PROCUREMENT DIVISION

CONCURRENCE BY: Roy Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE: 2/04/19

OTHER:

ACTION OF AWARDING AUTHORITY DATE 2/04/19

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Mousa
Chief Administrative Officer
For: Mayor Leany Curry
Under Authority of:
Executive Order No 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to amend and increase piggyback award with Johnson Controls, Inc. (contract #9572-04), to add funding for fiscal year 19 in the amount of $300,000.00 for as needed basis for City-wide Heating, Ventilation and Air Conditioning (HVAC) Equipment. Total revised award amount not-to-exceed $1,350,416.01.

This award to be funded by account: PWPBSA1MAPR-03410 to be executed by contract amendment through Office of General Counsel.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: MARILYN LAIDLER RESPECTFULLY SUBMITTED GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Roy Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE: 11/15/18

OTHER

ACTION OF AWARDING AUTHORITY DATE 11/15/18

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Mouss
Chief Administrative Officer
For, Mayor Lenny Curry
Under Authority of
Executive Order No 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-159CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to amend and increase piggyback award with Johnson Controls, Inc. (contract#59572-04), to add funding for fiscal year 18 in the amount of $150,000.00 for as needed basis for City-wide Heating, Ventilation and Air Conditioning (HVAC) Equipment. Unencumber unused funds in the amount of $17,193.99 from award approved on 11/10/17 (Amendment No 2) due to project came in under budget, CITFW18000035-04, Account No. FWCP32EPB519-062505-PW0118-02. Total revised award amount not-to-exceed $1,050,416.01.

This award to be funded by account FWPBSA1MAPR-03410 to be executed by contract amendment through Office of General Counsel.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: MARILYN LADLER RESPECTFULLY SUBMITTED: GREGORY PEACE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Rey Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE: 8/09/18

OTHER

ACTION OF AWARDING AUTHORITY DATE 8/9/18

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Chief Administrative Officer
For Mayor Lenny Curry
Under Authority of Ordinance No. 2015-03

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to amend piggyback award with Johnson Controls, Inc. (contract#9572-04), to add funding in the amount of $150,000.00 for as needed basis for City-wide Heating, Ventilation and Air Conditioning (HVAC) Equipment, also amend to add funding for HVAC Facility Services to include inspections and Preventative Maintenance along with Scheduled Service Materials on Chiller and Chiller related equipment., in the amount of $67,500.00 at $5,625.00 per month for one (1) year (February 1, 2018 – January 31, 2019). Total revised award amount not-to-exceed $717,610.00.

This award to be funded by account: PWPBSA1MAPR-03410 to be executed by contract amendment through Office of General Counsel.

Attachments: Recommendation Memo, Vendor Proposal, Previous Award(s)

BUYER: MARILYN LAIDLER RESPECTFULLY SUBMITTED GREGORY FEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Roy Birbal, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING 0 DATE: 1-25-19

OTHER.

ACTION OF AWARDING AUTHORITY DATE 1/25/19

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Mousa
Chief Administrative Officer
Facilities Management Division
Under Authority of
Executive Order No. 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT [illegible] FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0110-17 OPEN DATE:

OVERALL CONTRACT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT-FROM DATE OF AWARD THROUGH AUGUST 31, 2018

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER: ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to increase the piggyback award with Johnson Controls, Inc. to add funding in the amount of $250,000.00 for chiller replacement and necessary repairs at the Frank Osborne Convention Center. Total revised award amount not to exceed $500,110.00.

This award to be funded by account: PWCP30 EPBS15 OEMOS-PWC577-01 to be executed by Lump contract through Office of General Counsel.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: [signature] for MARILYN LAICHER

RESPECTFULLY SUBMITTED [signature] GREGORY FEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: For Bureau Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF OGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE 11/09/17

[signature] OTHER:

[signature]

[signature]

ACTION OF AWARDING AUTHORITY DATE 11/10/17

IAW APPROVED [signature] DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION [signature]
Tom E. Fogle
Chief Administrative Officer
The Urban Living Corp
Under Authority of
Executive Order No 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT #GS-07F-[illegible]CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-17 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT - FROM DATE OF AWARD THROUGH AUGUST 31, 2019

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to award piggyback award with Johnson Controls, Inc., for additional labor amount of $100,110.00 for work to be performed at the Main Library. Total revised award amount not to exceed $250,110.00

This award to be funded by account: PLCP2025F5710-[illegible]-PLCP2-[illegible] to be executed by formal contract through Office of General Counsel.

Attachments: Recommendation Memo, Previous Award(s)

BUYER: MARILYN LANDER RESPECTFULLY SUBMITTED GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: For Rental, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING 0 DATE: 7/28/17

OTHER

ACTION OF AWARDING AUTHORITY DATE 7/28/17

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Maura
Chief Administrative Officer
For Mayor Lenny Curry
Under Authority of
Executive Order No. 2015-05

SUBJECT: PIGGYBACK GSA CONTRACT 805-DJF-LGGCA FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0470-11 OPEN DATE:

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31, 2020

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED: ( ) NUMBER RECEIVED: ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Recommend approval to extend piggyback award approved on 04/13/17 with Johnson Controls, Inc., by adding Exhibit 2 (Administration) and Exhibit 3 (Insurance Requirements) per Risk Management Department which were inadvertently omitted from the original request/package. The Exhibits are to made part of the formal contract through Office of General Counsel.

Attachments: Recommendation Memo, Previous Award

BUYER: Karily Kaufler KARILY KAUFLER RESPECTFULLY SUBMITTED: GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Ray Gibbel, Chief, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING 0 DATE: 6/5/17

OTHER:

ACTION OF AWARDING AUTHORITY DATE 6/05/17

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION:

Chief Administrative Officer
For Mayor Lenny Curry
Under Authority of
Executive Order No. 2013-05

SUBJECT: PIGGYBACK GSA CONTRACT GS-07F-190CA, FOR HVAC EQUIPMENT, INSTALLATION AND FACILITY SERVICES

BID #: PSC-0170-17 OPEN DATE:

GENERAL GOVERNMENT AWARD COMMITTEE

KIND AND BASIS OF CONTRACT: PIGGYBACK CONTRACT- FROM DATE OF AWARD THROUGH AUGUST 31 2021

AGENCY: PUBLIC BUILDINGS

BASIS OF AWARD: PER PIGGYBACK CONTRACT

NUMBER OF BIDS INVITED ( ) NUMBER RECEIVED. ( ) OTHER ( )

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Purchase of general maintenance GSA Contract GS-07F-190CA with Johnson Controls, Inc. for HVAC Equipment, Installation and Facility Services on an as needed basis. Period of Service will be from date of award through August 31 2021. Total award amount not to exceed $150,000.00

This award to be funded by account: PW/PS/AHMA/PI (Contingent on approval by Council through the Office of General Counsel.

Attachments: Purchase Order Request, GSA Contract and pricing

SUBMITTED: MARK WINDLER RESPECTFULLY SUBMITTED: GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE OF: Chief Public Buildings Officer, Public Buildings Division

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING 0 DATE 2/13/17

OTHER:

ACTION OF AWARDING AUTHORITY DATE 4/17/17

APPROVED DISAPPROVED

OTHER

SIGNATURE OF AUTHENTICATION

Sam E. Hall
Chief Administrative Officer
For Mayor Lenny Curry
Under Authority of
Executive Order No. 2015-05

PSC-0470-17	Johnson Controls, Inc.	
4/13/2017	$150,000.00	Award
6/5/2017		Amended to Add Exhibits only
7/29/2017	$100,110.00	Amended to Add Main Libarary
11/9/2017	$250,000.00	Increase for Chiller Replacement at Prime Osbourne
1/25/2018	$217,500.00	Increase
8/9/2018	-$17,193.99	Unencumber unused funds from award approved on 11/10/17
8/9/2018	$350,000.00	FY 18 funds increase
11/15/2018	$300,000.00	FY 19 funds increase
2/4/2019		Breakdown of areas no increase in amount
4/25/2019	$1,500,000.00	Increase
10/24/2019	$ 1,000,000.00	Increase
Pending	$ 61,452.37	Increase
	$3,911,868.38	**Total Award**